

Field Site Power Data Acquisition and System Reporting

Kenneth Shipley - ITS Engineer

Caltrans, District 2

2021

Overview

- Background
- Relay Project Initiated
- Design Decisions and Architecture
- Implementation
- Examples



Overview

- Complications
- Integration
- Lessons Learned
- Questions

Home | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#) Powered By D2 ITS

On Inverter: ■
 On Buck/Boost: ■
 Data is stale (>2Hrs): ■
 Down for construction: ■
 Event Occurred Last 24Hrs: !

Current Site Status

All Sites

Sites With Errors New Site

Site	Current Mode	Power (In, Out, Out, Batt)	Battery Manufacture	Time in Error	Last Successful Pull
Abrams_Lake	Line	121.0V 119.0V 178VA 55.3V	Jul 2018	-	09:35:36 08-30-2021
Abrams_Lake_NB	Line	121.0V 119.0V 178VA 53.3V	Apr 2016	-	09:34:36 08-30-2021
Abrams_Lake_SB	Line	122.0V 121.0V 145VA 55.1V	Jul 2018	-	09:35:36 08-30-2021
Anderson_Grade	Line	117.5V 117.0V 187VA 53.1V	Sep 2019	-	09:32:08 08-30-2021
Antlers_Bridge	Line	118.5V 118.0V 236VA 53.2V	Jun 2019	-	09:35:35 08-30-2021
Black_Butte	Line	120.0V 119.0V 178VA 53.3V	Apr 2016	-	09:22:35 08-30-2021
! Bogard	Line	122.5V 122.0V 195VA 53.4V	Sep 2019	-	09:33:05 08-30-2021
Bowman_Rd	Line	123.0V 122.0V 183VA 54.3V	Sep 2012	-	08:57:37 08-30-2021
Buckhorn	Line	120.0V 119.0V 119VA 55.0V	Feb 2020	-	09:24:04 08-30-2021
Cedar_Pass	Line	118.0V 118.0V 129VA 53.6V	Mar 2012	-	09:04:05 08-30-2021
Central_Yreka	Line	121.0V 117.0V 117VA 53.4V	Feb 2016	-	08:36:38 08-30-2021
Collier	Line	122.0V 121.0V 121VA 53.4V	Dec 2018	-	09:08:39 08-30-2021
Cottonwood_Truck_Scales	Line	123.0V 122.0V 195VA 54.2V	Jul 2018	-	09:34:37 08-30-2021
Deschutes	Inverter	0.0V 120.0V 132VA 43.7V	Mar 2010	-	03:08:37 08-17-2021
Dorris	Line	122.0V 120.0V 108VA 54.0V	Jan 2017	0:26:19	08:40:02 08-30-2021
! Doyle	Line	121.0V 120.0V 204VA 53.1V	Jun 2019	-	09:34:37 08-30-2021
Dunsmuir	Line	119.0V 118.0V 129VA 53.3V	Feb 2016	-	09:31:39 08-30-2021
East_Riverside	Line	123.0V 121.0V 157VA 53.1V	Feb 2020	-	09:12:05 08-30-2021
EELab_1921	Line	115.0V 114.0V 193VA 54.2V	Nov 2014	2:34:44	06:47:05 08-30-2021
EELab_SNMP	Line	116.0V 115.0V 195VA 54.3V	Jan 2010	-	09:32:00 08-30-2021
Eureka_Way	Line	120.0V 118.0V 236VA 53.1V	Feb 2016	-	08:51:02 08-30-2021
Fawndale	Line	123.0V 122.0V 341VA 53.1V	Jun 2019	-	09:32:00 08-30-2021
Fredonier_Smt	Line	117.5V 117.0V 163VA 55.0V	Feb 2016	-	11:07:39 05-24-2021

Background

- Unreliable power in rural areas during inclement weather
- Install Battery Backup System (BBS) at Closed Circuit Television (CCTV) camera
- Increased perceived reliability



Background – Unreliable Power

- Unreliable power in rural areas during inclement weather
- Equipment at a field site would reset
- Cameras looking in unusable locations
- Large amounts of time spent re-aiming cameras
- Routers losing configurations/flash because of the hard power shutoffs

Background – Solution

- Install BBS at all CCTV Locations
- Possible Inverter Options
- Battery Chosen



Background – Inverter Requirements

- Must meet ITI (CBEMA) Curve
- Must fit in ITS Cabinet and/or Pony Cabinet
- Must be able to provide sufficient power to field site

Background – ITI (CBEMA) Curve

- ITI: Information Technology Industry Council
- CBEMA: Computer Business Equipment Manufacturers Association


Background – ITI (CBEMA) Curve

- A power acceptability curve for sensitive electronics.
- Experimental and historical data from mainframe computers was used to create the CBEMA curve
- ITI Uses a modified version of the CBEMA Curve

Bas

ve


ITI (CBEMA) Curve
(Revised 2000)



Source: [ITI](#)

Background – ITI (CBEMA) Curve


- The curve is broken up into three parts
- The Acceptable Region



Source: [ITI](#)


Background – ITI (CBEMA) Curve

- The acceptable region
 - The region in which the equipment will continue to run without interruption
 - This determines the transfer time for the inverter
 - This will stop the cameras and routers power cycling for short bursts of power interruptions




Background – ITI (CBEMA) Curve

- The curve is broken up into three parts
- The Acceptable Region
- The No Damage Region




Background – ITI (CBEMA) Curve

- The “No Damage” region
 - This region is where there will be no damage to the equipment
 - There will still be loss of power to equipment




Background – ITI (CBEMA) Curve

- The curve is broken up into three parts
- The Acceptable Region
- The No Damage Region
- The Prohibited Region



Background – ITI (CBEMA) Curve


- The “Prohibited” region
 - This region is where we would start to see equipment being damaged
 - Want to avoid this region in the curve



Bas

ve

ITI (CBEMA) Curve
(Revised 2000)



Source: [ITI](#)

Background – Other Requirements

- Needs to be rack mountable
- Range of power output for field site 150-500 Watts

Background – Inverter Option 1

- Alpha FXM 1100



Background – Inverter Option 1 Specifications

- 1100 Watts
- 20 Amp Input Current
- 15.5 Max Charge Current
- 5 ms Transfer time



Background – Inverter Option 1 Specifications

- W x D x H : 15.5" x 8.75" x 5.22"
- Will default float charge batteries at 54V
- Temperature compensated battery charger -5 mV/°C/Cell
 - User can Adjust between 0 to -6 mV



Background – Inverter Option 2

- Made by Dimensions
- What was stocked in the state warehouse



Background – Inverter Option 2 Specifications

- 1100-1700 Watts temperature dependent
- 60 ms Transfer Time
- W x D x H : 16.5" x 12" x 6"
- Temperature compensated battery charger 2.5-4.0 mV/°C



Background – Inverter Option 3

- Myers by Power Products, Inc.
- Previous inverter located at a few sites



Background – Inverter Option 3 Specifications

- 1500 Watts
- Max input current 20 A
- 10 A Max Charge Current
- 7ms Transfer Time
- W x D x H : 17" x 11" x 5.25"



Background – Inverter Chosen

Alpha FXM 1100


- Met ITI(CBEMA) Curve requirements
- Required amount power outputted
- Unit operating temperature within acceptable range



Background – Inverter Chosen

Dimensions ADI-48M17

- Did not meet the CBEMA Curve for electronic switching time
- Did not consider due to this



Background – Inverter Chosen

Myers UPS MP2000

- Met the ITI (CBEMA) Curve for electronic switching time
 - By 1.33ms
- Every time a field site would lose power the inverter would go into a fault state that would not power the site after power was restored
- Quality Assurance QA from company seemed to be hit or miss


Background – Battery

- UPS Battery chosen
 - Consistent discharge
 - Supports float charge
- Deep Cycle battery not considered
 - Should not be float charged
- Car/mobility battery not considered
 - Short burst of amperage to start engines

Background – Battery

- C&D Technologies
UPS12-300MR
- These batteries have an Absorbent Glass Mat to minimize off gassing
 - This avoids pressure building up inside the battery

Background – Battery



Background – Battery

- C&D Technologies
UPS12-300MR
- These batteries have an Absorbent Glass Mat to minimize off gassing
 - This avoids pressure building up inside the battery



Background – Battery

C&D Technologies UPS12-300MR

- Absorbent Glass Mat (AGM)
 - A thin fiberglass mat inside the battery around the cells
 - Allows the battery to be completely sealed and spill proof
 - Captures the gas inside the battery to minimize off gassing



⚠ DANGER/POISON
NON SPILLABLE BATTERY

SHIELD EYES EXPLOSIVE GASES CAN CAUSE BLINDNESS OR INJURY

NO SPARKS, FLAMES, OR SMOKING

SULFURIC ACID CAN CAUSE BLINDNESS OR SEVERE BURNS

FLUSH EYES IMMEDIATELY WITH WATER
 GET MEDICAL HELP FAST. KEEP OUT OF REACH OF CHILDREN

CALIF. PROPOSITION 65 WARNING
 Battery posts, terminals and related accessories contain lead and lead compounds, chemicals known to the State of California to cause cancer and reproductive harm. Batteries also contain other chemicals known to the State of California to cause cancer. Wash hands after handling.

0619
 WARRANTY DATE/LAST CHARGE DATE

MADE IN MEXICO

QUALITY MANAGEMENT SYSTEM
CREATED BY ISO
190 9001 IFL 9000



PROPOSITION 65 WARNING
Battery posts, terminals and related accessories contain lead and lead compounds, chemicals known to the State of California to cause cancer and reproductive harm. Wash hands after handling.

HIGH RATE MAX

CD TECHNOLOGIES® UPS

UPS12-300MR
(Manufacturer Approved Premium Replacement for UPS12-270FR & MR12-300)

<p>12 Volts <small>(20 hour rate to 1.75 VPC @ 77°F)</small></p> <p>77.8 AH <small>(20 hour rate to 1.75 VPC @ 77°F)</small></p> <p>Terminal Hardware Torque: <small>110 in. - lbs. (12.4 N-m)</small></p>	<p>300 WPC <small>(15 minute rate to 1.67 VPC @ 77°F)</small></p> <p>Float Charge Voltage: <small>13.5 to 13.8 VDC @ 77°F (25°C)</small></p> <p>IEC Rating: 71.3 AH <small>(10 hour rate to 1.80 VPC @ 20°C)</small></p> <p>NON-SPILLABLE</p>
---	--


VENTILATE WELL WHEN IN AN ENCLOSED SPACE AND WHEN CHARGING.
SEE INSTALLATION, MAINTENANCE AND OPERATION INSTRUCTIONS FOR IMPORTANT SAFETY PRECAUTIONS.

(+1) 215-619-2700 www.cdtechno.com Made in Mexico 10100901



UPS12-300MR







Background – Results


- Hardware at field sites maintain power when short bursts of power loss
- Cameras not going through start up procedure and oriented in useable home direction

! I5-SR299	Line	122.0V 121.0V 205VA 54.1V	Sep 2016	-	06:54:35 07-21-2021
I5-SR44			Sep 2019	-	06:53:35 07-21-2021
I5-SR89			Apr 2013	-	06:27:58 07-21-2021
I5-US97			Sep 2012	-	06:25:39 07-21-2021
Janesville			Jun 2019	7:56:21	05:59:36 07-21-2021
Jellys_Ferry			Sep 2012	-	06:32:40 07-21-2021
Johnson_Grade			Jan 2011	-	06:31:05 07-21-2021
Johnson_Park			Jun 2019	-	06:27:30 07-21-2021
Lakehead			Nov 2011	-	06:51:35 07-21-2021
! Lake_Blvd			Jun 2019	-	06:55:35 07-21-2021
Lake_BlvdUPS			Jun 2019	-	06:55:00 07-21-2021
Lassen_Park			Jun 2019	-	06:21:51 07-21-2021
La_Moine			Apr 2013	-	06:54:35 07-21-2021
Montgomery_Creek			Sep 2012	-	05:57:09 07-21-2021
Mott_Rd	Line	119.0V 118.0V 70VA 53.1V	Sep 2019	-	06:06:39 07-21-2021



Background – Results

- Less time re-aiming cameras
- Routers not losing flash and not power cycling


! I5-SR299	Line	122.0V	124.0V	205VA	54.4V	Sep 2016	-	06:54:35	07-21-2021					
I5-SR44						Sep 2019	-	06:53:35	07-21-2021					
I5-SR89						Apr 2013	-	06:27:58	07-21-2021					
I5-US97						Sep 2012	-	06:25:39	07-21-2021					
Janesville						Jun 2019	7:56:21	05:59:36	07-21-2021					
Jellys_Ferry						Sep 2012	-	06:32:40	07-21-2021					
Johnson_Grade						Jan 2011	-	06:31:05	07-21-2021					
Johnson_Park						Jun 2019	-	06:27:30	07-21-2021					
Lakehead						Nov 2011	-	06:51:35	07-21-2021					
! Lake_Blvd						Jun 2019	-	06:55:35	07-21-2021					
Lake_BlvdUPS						Jun 2019	-	06:55:00	07-21-2021					
Lassen_Park						Jun 2019	-	06:21:51	07-21-2021					
La_Moine						Apr 2013	-	06:54:35	07-21-2021					
Montgomery_Creek						Sep 2012	-	05:57:09	07-21-2021					
Mott_Rd						Line	119.0V	118.0V	70VA	53.1V	Sep 2019	-	06:06:39	07-21-2021

Relay Project Initiated

- Retrieve Current Power Status
- Maintain power history for each field site for trends
- Display on web based Graphical User Interface (GUI)

Relay Project – Power Status

- From the District office retrieve the current power status of a field site



Relay Project – Power History

- Store the power status retrieved to see trends on a site-by-site basis


Oregon Mtn Power Stats

Graph last 365 day(s)

[View Table](#) | [View Events](#)

[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)

[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)



Relay Project – Web GUI

- Power failure at field site and running on Battery Backup
- Power trend history graphs


Oregon Mtn Power Stats

Graph last 365 day(s)

[View Table](#) | [View Events](#)

[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)

[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)



Relay Project – Web GUI

- Battery Status
 - Estimated time before total power loss
 - Age of Batteries, Replacement history


Janesville Power Stats

Graph last 3 day(s)

[View Table](#) | [View Events](#)

[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)


[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)



Design

- Hardware used
- Communications to the Alpha FXM 1100
- Software used for development

Design




Design – Hardware

- Webserver hosted on a Virtual Machine (VM)
- Alpha FXM 1100
- Moxa at field site
 - Needed for communications to the Alpha



Design – Hardware

- Moxa at field site
 - Existing device at field sites used for PTZ of our cameras
 - It has multiple ports
 - Utilize port 2 of Moxa for communication to Alpha



Design – Communications

- Serial Communication

Design

Options

- Serial Comm




Design – Communications

- Serial Communication
 - Cable from ITS Node to BBS Cabinet
 - Moxa port configured for communications to Alpha
 - This is only way to communicate to older units as they do not have ethernet port




Design – Communications

- Serial Communication (PROS)
 - Allows for event history.
 - Limited information.
 - Provides Power States, Alarm, and Faults.
 - No Alpha configuration needed.



Design – Communications

- Serial Communication (CONS)
 - Power States, Alarms and Faults are in Binary and need to be parsed and converted to text.
 - POTS sites can timeout and not receive entire file resulting in missing information.




Design – Communications

- Ethernet

D


S

- Ethernet




Design – Communications

- Ethernet
 - Newer Alpha comes with ethernet port
 - Allows for SNMP
 - Does not need the Moxa
 - Still supports serial communications




Design – Communications

- Ethernet (PROS)
 - Can provide more information*
 - Power states, Alarms and Faults can be read in either binary or string format
 - Faster resulting in less timeouts and missing data
 - Can access web interface



Design – Communications


- Ethernet (CONS)
 - Unable to retrieve an event history with SNMP
 - Unit must be configured before it is usable



Design – Communications

- Both


- Both



ns

Design – Communications

- Both
 - Fast polling due to SNMP
 - Still have terminal access via serial connection



Design – Software

- Linux Ubuntu 18.04LTS
- Apache2
- MySQL
- Interpreted Scripting Language

Design – Software

- Ubuntu 18.04LTS
 - Less resources needed to run Linux Operating System (OS)
 - Easy to configure and develop on
 - Newest stable version
 - Easy to install



Source: [Wikipedia](#)

Design – Software

- Apache2
 - Reliable
 - Most successful web server
 - Runs on multiple operating systems
- MySQL
 - Scalable
 - High Performance


Design – Software

- Compiled language
 - C or C++
 - Fast
 - Source code protected




Design – Software

- Interpreted Scripting Language
 - Python and Perl
 - Good for development
 - Source code can be modified during runtime
 - Increasing effectiveness of debugging



Design – Software

- Interpreted Scripting Language
- Considerations
 - Python2
 - Perl



Design – Software

Python2

- Advantages
 - Familiarity
 - Good Support



Design – Software

Python2

- Advantages
 - Multiple modules to choose from
 - SNMP retrieval
 - Database integration
 - Good Thread Support



Design – Software

Python2

- Disadvantages
 - Slower then compiled language
 - Uses more memory



Design – Software

Perl

- Advantages
 - Good Support
 - Multiple modules to choose from
 - Good String manipulation



Source: [Wikipedia](#)

Design – Software

Perl

- Disadvantages
 - Unfamiliar
 - Slower than compiled language
 - Uses more memory



Source: [Wikipedia](#)

Design – Software

- Python2 chosen
 - Use of User Defined Functions
 - Familiarity
 - Better Thread Handling

Mt. Hebron, Lava Fire, June 2021



Implementation

- Deploy and establish communications to Alpha
- Database architecture and management
- Third party applications needed
- Process management options
- Programming languages used

Implementation – Deployment



Implementation – Deployment

- Older Alpha unit
- Most field sites have this unit
- Serial communication from Moxa only
- Firmware cannot be upgraded past 1.08.72 without issues



Implementation – Deployment



Implementation – Deployment


- Newer Alpha units
- Few field sites have this unit
- Comes with ethernet port allowing Simple Network Management Protocol (SNMP)
- Supports Serial communication from Moxa
- Firmware support to current firmware of 2.01.00




Implementation – Database

- MySQL used for local database
- Multiple tables were needed
 - Field Site configuration table
 - Current Power and Status tables
 - Running Power and Status tables


Database – Field Site Config

#	Name	Type	Collation	Attributes	Null	Default	Comments	Extra
<input type="checkbox"/>	1	Key 	int(4)		No	None		
<input type="checkbox"/>	2	Site	text	utf8_general_ci	No	None		
<input type="checkbox"/>	3	IP	varchar(13)	utf8_general_ci	No	None		
<input type="checkbox"/>	4	Port	int(4)		Yes	NULL		
<input type="checkbox"/>	5	CommType	varchar(10)	utf8_general_ci	No	None		
<input type="checkbox"/>	6	Timeout	int(3)		Yes	NULL		
<input type="checkbox"/>	7	AlphaCommType	varchar(6)	utf8_general_ci	No	None		
<input type="checkbox"/>	8	ExStartMin	int(2)		No	None		
<input type="checkbox"/>	9	ExOffset	int(2)		No	None		
<input type="checkbox"/>	10	DateFrmt	varchar(8)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	11	Down	tinyint(1)		No	None		
<input type="checkbox"/>	12	PingTO	smallint(3)		Yes	NULL		
<input type="checkbox"/>	13	Firmware	tinytext	utf8_general_ci	No	None		
<input type="checkbox"/>	14	CertUpdate	tinyint(1)		No	0		
<input type="checkbox"/>	15	RunningFlag	tinyint(1)		No	0		
<input type="checkbox"/>	16	Timestamp	timestamp	on update CURRENT_TIMESTAMP	No	CURRENT_TIMESTAMP		ON UPDATE CURRENT_TIMESTAMP
<input type="checkbox"/>	17	BattInstall	date		Yes	NULL		
<input type="checkbox"/>	18	CCTV	tinyint(1)		No	None		


Database – Current Event

#	Name	Type	Collation	Attributes	Null	Default	Comments	Extra
<input type="checkbox"/>	1	sitekey 	int(4)		Yes	NULL		
<input type="checkbox"/>	2	sitename	varchar(25)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	3	date	date		Yes	NULL		
<input type="checkbox"/>	4	time	varchar(8)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	5	alarms	varchar(16)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	6	faults	varchar(16)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	7	modecode	int(3)	UNSIGNED ZEROFILL	Yes	NULL		
<input type="checkbox"/>	8	mode	varchar(10)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	9	evdate	date		Yes	NULL		
<input type="checkbox"/>	10	evtime	time		Yes	NULL		
<input type="checkbox"/>	11	ivdate	date		Yes	NULL		
<input type="checkbox"/>	12	ivtime	time		Yes	NULL		
<input type="checkbox"/>	13	epochtime	decimal(12,2)		Yes	NULL		
<input type="checkbox"/>	14	errorState	tinyint(1)		No	0		
<input type="checkbox"/>	15	errorTime	datetime		Yes	NULL		
<input type="checkbox"/>	16	updateTime	timestamp	on update CURRENT_TIMESTAMP	No	CURRENT_TIMESTAMP		ON UPDATE CURRENT_TIMESTAMP


Database – Running Events

#	Name	Type	Collation	Attributes	Null	Default	Comments	Extra
<input type="checkbox"/>	1	sitekey 	int(4)		Yes	NULL		
<input type="checkbox"/>	2	date	date		Yes	NULL		
<input type="checkbox"/>	3	time	varchar(8)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	4	alarms	varchar(16)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	5	faults	varchar(16)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	6	modecode	int(3)	UNSIGNED ZEROFILL	Yes	NULL		
<input type="checkbox"/>	7	mode	varchar(10)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	8	evdate	date		Yes	NULL		
<input type="checkbox"/>	9	evtime	varchar(8)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	10	ivdate	date		Yes	NULL		
<input type="checkbox"/>	11	ivtime	varchar(8)	utf8_general_ci	Yes	NULL		
<input type="checkbox"/>	12	epochtime	decimal(12,2)		Yes	NULL		

Database – Current Power Stats

#	Name	Type	Collation	Attributes	Null	Default	Comments	Extra
<input type="checkbox"/>	1	sitekey 	int(4)		No	None		
<input type="checkbox"/>	2	inputVolt	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	3	inputHz	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	4	outputVolt	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	5	outputAmp	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	6	outputVA	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	7	battVolt	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	8	battTemp	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	9	mode	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	10	timestamp	timestamp		No	CURRENT_TIMESTAMP		

Database – Running Power Stats

#	Name	Type	Collation	Attributes	Null	Default	Comments	Extra
<input type="checkbox"/>	1	sitekey 	int(4)		No	None		
<input type="checkbox"/>	2	inputVolt	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	3	inputHz	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	4	outputVolt	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	5	outputAmp	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	6	outputVA	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	7	battVolt	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	8	battTemp	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	9	mode	text	latin1_swedish_ci	No	None		
<input type="checkbox"/>	10	timestamp	timestamp		No	CURRENT_TIMESTAMP		


Implementation – Database

- Php My Admin
 - Installed and hosted on local server
 - Used for database management
 - Allows for manual exporting, importing and backing up

Implementation – Third Party

- Plink – Chosen over pySerial
 - Is a tool from Putty that is used for sending commands to a remote device
 - Needed for the older Alpha units' lack of ethernet port
 - Opens a Secure Shell (SSH) connection
 - Allows for commands only to be sent to a serial device
 - Command line interface

Implementation – Third Party



Implementation – Third Party

- pySerial – Not used
 - This is used for serial connection on local machine
 - Moxa has an IP address with a configured port for the serial connection to the Alpha

Implementation – Process Management

- Requirements
 - Needs to run in background
 - Needs to log any issues
 - Needs to monitor process in background
 - Needs to start application at startup
 - Considerations:
 - Supervisor or daemon

Implementation – Process Management

- Supervisor
 - Monitors the background process
 - Allows logging of standard output, errors and process complications
 - Launches backend process at startup
 - Monitors and ensure process is continuously running

Implementation – Process Management

- Supervisor
 - Reads in program configuration file for fine tuning process automation
 - Written in Python
 - If main thread of program unable to start and stay running for more then 1sec, 3 times, manual intervention is required

Implementation – Process Management

- Daemon
 - Process must be started with init
 - Logging must be done within process
 - Does not monitor process to ensure startup

Implementation – Process Management

- Supervisor Chosen
- Process Configuration Options
- Process Monitoring
- Process Logging

```
[program:bbs]
command=/var/bbs/bbs/main.py
autostart=true
directory=/var/bbs/bbs
user=username
stderr_logfile=/var/bbs/supervisor_logs/bbs_err.log
stdout_logfile=/var/bbs/supervisor_logs/bbs_out.log
stderr_logfile_maxbytes=5MB
stderr_logfile_backups=5
stdout_logfile_maxbytes=5MB
stdout_logfile_backups=5
```

Implementation – Programming Languages

- Python2
- Bash
- HTML
- JavaScript
- CSS



Source: [World Wide Web Consortium](http://www.w3.org/)

Implementation – Programming Languages


- Python2
 - Already installed on server
 - Backend written primarily in Python
 - Frontend written in HTML utilizing Python CGI
- Bash
 - In conjunction with plink writes a text file to server
- HTML, JavaScript, and CSS
 - Website design

Implementation – Programming Languages

- Python – Backend
 - Database integration
 - Checks field site time to run
 - Launches field site using threads
 - Uses bash to run OS subroutines
 - Text Parsing from serial communication

```
-- bbs
|-- Comm.py
|-- eventmonth.py
|-- Event.py
|-- log.py
|-- main.py (x)
|-- paths.py (Generic)
|-- power.py
|-- siteread.py
|-- SNMP.py
|-- SNMP_SQL.py
|-- startup.py
`-- validate.py
```

Implementation – Programming Languages



Implementation – Programming Languages

- Python – Frontend
 - Common Gateway Interface (CGI) for seemingly dynamic Graphical User Interface (GUI)
 - Database integration
 - Allows for configuration of field site, and system

```
-- ui
|  -- js
|  |  -- Chart.js
|  |  -- FileSaver.js
|  |  -- jquery.tablesorter.js
|  |  -- jquery-3.3.1.js
|  |  -- moment.js
|  |  -- valid.js
|  -- __init__.py
|  -- allsites.py (x)
|  -- graphs.py (x)
|  -- helper.py (x)
|  -- logs.py (x)
|  -- modify.py (x)
|  -- power.py (x)
|  -- siteconfig.py (x)
|  -- siteinfo.py (x)
|-- style.css
```

Implementation – Programming Languages

- HTML
 - Base code for the GUI
- JavaScript
 - Graph display
 - Data Validation
- CSS
 - Styling of webpage items

Implementation – Programming Languages

```
import sys
import cgi, cgitb, httplib
from datetime import datetime, timedelta

import pymysql

sys.path.insert(0, '/var/bbs/bbs/')
import paths
from helper import decode_al_fa, htmlheader, banner, htmlheader_refresh, legend, updateFirmware, maintenance, footer

cgitb.enable()
```

- CSS
 - Styling of webpage items

Implementation – Programming Languages

```
import sys
import cgi, cgitb, httplib
from datetime import datetime, timedelta

import pymysql

sys.path.insert(0, '/var/bbs/bbs/')
import paths
from helper import decode_al_fa, htmlheader, banner, htmlheader_refresh, legend, updateFirmware, maintenance, footer

cgitb.enable()
```

- CSS
- Styling of webp

```
# Banner at top of page
banner()

# Header
print('''
<title>District 2 Battery Backup Status</title>
<div style="width:850px;">
  <div style="width:500px; float:left;">
    <h1 align = left>Current Site Status</h1>
    <h2 align = left>All Sites</h2>
  </div>
''')

# Legend
legend()
```

Implementation – Programming Languages

- Python – Third party modules that needed to be installed
 - Pymysql – MySQL Python integration
 - Easysnmp – SNMP Python integration

Implementation – Programming Languages

```
# Function: saveStats
# Args: stats -> list of power stats
#       siteName -> the name of the site
# Saves the power statistics to the running log of stats into the DB
def saveStats(stats, siteName):

    conn = pymysql.connect(
        db=paths.database,
        user=paths.user,
        passwd=paths.passwd,
        host=paths.host)
    c = conn.cursor()
    try:
        c.execute('''INSERT INTO `power`(`sitekey`, `inputVolt`, `inputHz`, `outputVolt`, `outputAmp`,
            `outputVA`, `battVolt`, `battTemp`, `mode`) VALUES(
            {}, '{}', '{}', '{}', '{}', '{}', '{}', '{}', '{}')'''.format(stats[sitekey], stats[inputVolt],
            stats[inputHz], stats[outputVolt], stats[outputAmp], stats[outputVA], stats[battVolt], stats[battTemp], stats[mode]))
        conn.commit()
    except pymysql.MySQLError as e:
        miscSiteLog(siteName, "There was a SQL error {} saving power stats".format(e))
    finally:
        c.close()
        conn.close()
```


Implementation – Programming Languages

```
# Function: saveStats
# Args: stats -> list of power stats
#       siteName -> the name of the site
# Saves the power statistics to the running log of stats into the DB
def saveStats(stats, siteName):

    conn = pymysql.connect(
        db=paths.database,
        user=paths.user,
        passwd=paths.passwd,
        host=paths.host)
    c = conn.cursor()
    try:
        c.execute('''INSERT INTO `power`(`sitekey`, `inputVolt`, `inputHz`, `outputVolt`, `outputAmp`,
            `outputVA`, `battVolt`, `battTemp`, `mode`) VALUES(
            {}, '{}', '{}', '{}', '{}', '{}', '{}', '{}', '{}')'''.format(stats[sitekey], stats[inputVolt],
            stats[inputHz], stats[outputVolt], stats[outputAmp], stats[outputVA], stats[battVolt], stats[battTemp], stats[mode]))
        conn.commit()
    except pymysql.MySQLError as e:
        miscSiteLog(siteName, "There was a SQL error {} saving power stats".format(e))
    finally:
        c.close()
        conn.close()
```

```
# Function: setUpSesh
# Will take the sites IP address and open a session to that site.
def setUpSesh(ip, community = 'public'):
    session = Session(hostname = ip, community = community, version=2, use_sprint_value=True, timeout=10)
    return session
```

Implementation – Programming Languages

- Bash
 - Called by the backend Python script
 - Was needed to use the third-party applications plink to communicate via serial communication
 - Once plink has established SSH connection allows the writing of text file
 - Calling bash commands from Python can be tricky
 - Used to call system level commands
 - Will ping site to confirm communications

```
[0 - Main Menu]
[2 - Input / Output Values]
Input: 119.0V 60.0Hz
Output: 117.0V 1.6A 187VA
Battery: 52.8V 28Deg C

*clock=21-07-21 10:36:36

[0 - Main Menu]
[1 - Unit Specification]
Model: FXM1100
Input: 120V 60Hz
Output: 120V 1100VA
Battery: 48V
Software: V2.01.00

*event001=21-07-11 22:06:05 0000000000000000, 0000000000000000, 001
*event002=21-07-11 22:05:58 0000000000000000, 0000000000000000, 006
*event003=21-07-04 22:56:13 0000000000000000, 0000000000000000, 001
*event004=21-07-04 22:55:12 0000000000000000, 0000000000000000, 003
*event005=21-07-04 22:55:07 0000000000000000, 0000000000000000, 001
*event006=21-07-04 22:55:01 1000000000000000, 0000000000000000, 001
*event007=21-07-04 20:23:53 1000000000000000, 0000000000000000, 006
*event008=21-07-04 20:22:50 0000000000000000, 0000000000000000, 006
*event009=21-06-30 13:54:40 0000000000000000, 0000000000000000, 001
*event010=21-06-30 13:54:35 1000000000000000, 0000000000000000, 001
*event011=21-06-30 13:54:30 1000000000000000, 0000000000000000, 006
*event012=21-06-30 13:50:39 1000000010000000, 0000000000000000, 006
*event013=21-06-30 13:49:37 0000000010000000, 0000000000000000, 006
*event014=21-06-30 13:49:36 0000000000000000, 0000000000000000, 006
*event015=21-06-30 10:47:02 0000000000000000, 0000000000000000, 001
*event016=21-06-30 10:46:56 0000000000000000, 0000000000000000, 006
*event017=21-06-24 14:00:45 0000000000000000, 0000000000000000, 001
*event018=21-06-24 14:00:38 0000000000000000, 0000000000000000, 006
*event019=21-06-22 18:37:29 0000000000000000, 0000000000000000, 001
*event020=21-06-22 18:37:28 0000000000000000, 0000000000000000, 003
*event021=21-06-14 18:02:09 0000000000000000, 0000000000000000, 001
*event022=21-06-14 18:02:03 1000000000000000, 0000000000000000, 001
*event023=21-06-14 17:53:33 1000000000000000, 0000000000000000, 006
*event024=21-06-14 17:52:30 0000000000000000, 0000000000000000, 006
*event025=21-06-09 00:49:06 0000000000000000, 0000000000000000, 001
```

on – Programming Languages

Python script

Third-party applications link to communication

and SSH connection allows the writing of text

Some Python can be tricky

Commands

Communications

on – Programming anguages

```
[0 - Main Menu]
[2 - Input / Output Values]
Input: 119.0V 60.0Hz
Output: 117.0V 1.6A 187VA
Battery: 52.8V 28Deg C
*clock=21-07-21 10:36:36
```

```
[0 - Main Menu]
[1 - Unit Specification]
Model: FXM1100
Input: 120V 60Hz
Output: 120V 1100VA
Battery: 48V
Software: V2.01.00
```

```
*event001=21-07-11 22:06:05 0000000000000000, 0000000000000000, 001
*event002=21-07-11 22:05:58 0000000000000000, 0000000000000000, 006
*event003=21-07-04 22:56:13 0000000000000000, 0000000000000000, 001
*event004=21-07-04 22:55:12 0000000000000000, 0000000000000000, 003
*event005=21-07-04 22:55:07 0000000000000000, 0000000000000000, 001
*event006=21-07-04 22:55:01 1000000000000000, 0000000000000000, 001
*event007=21-07-04 20:23:53 1000000000000000, 0000000000000000, 006
*event008=21-07-04 20:22:50 0000000000000000, 0000000000000000, 006
*event009=21-06-30 13:54:40 0000000000000000, 0000000000000000, 001
*event010=21-06-30 13:54:35 1000000000000000, 0000000000000000, 001
*event011=21-06-30 13:54:30 1000000000000000, 0000000000000000, 006
*event012=21-06-30 13:50:39 1000000010000000, 0000000000000000, 006
*event013=21-06-30 13:49:37 0000000010000000, 0000000000000000, 006
*event014=21-06-30 13:49:36 0000000000000000, 0000000000000000, 006
*event015=21-06-30 10:47:02 0000000000000000, 0000000000000000, 001
*event016=21-06-30 10:46:56 0000000000000000, 0000000000000000, 006
*event017=21-06-24 14:00:45 0000000000000000, 0000000000000000, 001
*event018=21-06-24 14:00:38 0000000000000000, 0000000000000000, 006
*event019=21-06-22 18:37:29 0000000000000000, 0000000000000000, 001
*event020=21-06-22 18:37:28 0000000000000000, 0000000000000000, 003
*event021=21-06-14 18:02:09 0000000000000000, 0000000000000000, 001
*event022=21-06-14 18:02:03 1000000000000000, 0000000000000000, 001
*event023=21-06-14 17:53:33 1000000000000000, 0000000000000000, 006
*event024=21-06-14 17:52:30 0000000000000000, 0000000000000000, 006
*event025=21-06-09 00:49:06 0000000000000000, 0000000000000000, 001
```

hon script

rd-
mr
d S
om
om
om

```
[0 - Main Menu]
[2 - Input / Output Values]
Input: 122.0V 60.0Hz
Output: 122.0V 1.6A 195VA
Battery: 52.7V 20Deg C
*clock=07-21-21 10:32:22

[0 - Main Menu]
[1 - Unit Specification]
Model: FXM1100
Input: 120V 60Hz
Output: 120V 1100VA
Battery: 48V
Software: V1.08.72

*event001=07-19-21 12:06:08 0000000000000000, 0000000000000000, 001
*event002=07-19-21 12:06:01 0000000000000000, 0000000000000000, 006
*event003=07-19-21 12:05:57 0000000000000000, 0000000000000000, 001
*event004=07-19-21 12:05:50 0000000000000000, 0000000000000000, 006
*event005=07-19-21 11:49:28 0000000000000000, 0000000000000000, 001
*event006=07-19-21 11:49:21 0000000000000000, 0000000000000000, 006
*event007=07-19-21 11:40:10 0000000000000000, 0000000000000000
```

xt

Implementation – Programming Languages

- JavaScript – Third party modules used
 - JQuery-3.3.1.js – wide variety of uses
 - JQuery.tablesorter.js – Used to sort power table by name
 - Chart.js - Graph display
 - Moment.js – used by Chart.js for date integration

Examples

- Live demo of website
 - If successful skip next slide (slide 128)

Examples - Homepage

- First Example is of the system functioning normally

Current Site Status

All Sites

On Inverter: ■
 On Buck/Boost: ■
 Data is stale (>2Hrs): ■
 Down for construction: ■
 Event Occurred Last 24Hrs: !

ge

, normally

Sites With Errors

[New Site](#)

Site	Current Mode	Power (In, Out, Out, Batt)	Battery Manufacture	Time in Error	Last Successful Pull
Abrams_Lake	Line	120.0V 119.0V 202VA 54.8V	Jul 2018	-	07:35:35 07-27-2021
Abrams_Lake_NB	Line	120.0V 118.0V 177VA 53.2V	Apr 2016	-	07:34:36 07-27-2021
Abrams_Lake_SB	Line	122.0V 120.0V 144VA 54.6V	Jul 2018	-	07:35:35 07-27-2021
Anderson_Grade	Line	117.0V 116.0V 185VA 52.6V	Sep 2019	-	07:32:08 07-27-2021
! Antlers_Bridge	Line	119.0V 118.0V 236VA 52.9V	Jul 2009	-	07:35:35 07-27-2021
Black_Butte	Line	120.5V 120.0V 204VA 52.9V	Apr 2016	-	07:22:35 07-27-2021
Bogard	Line	122.5V 124.0V 198VA 53.4V	Sep 2019	-	07:33:04 07-27-2021
! Bowman_Rd	Line	124.0V 123.0V 184VA 54.2V	Sep 2012	-	06:57:37 07-27-2021
Buckhorn	Line	120.0V 119.0V 107VA 54.4V	Dec 2006	-	07:24:39 07-27-2021
Cedar_Pass	Line	119.0V 118.0V 129VA 53.4V	Mar 2012	-	07:04:09 07-27-2021
Central_Yreka	Line	119.0V 115.0V 126VA 52.9V	Feb 2016	-	06:36:38 07-27-2021
Collier	Line	122.0V 120.0V 216VA 36.2V	Dec 2018	-	07:08:43 07-27-2021
! Cottonwood_Truck_Scales	Line	124.0V 122.0V 195VA 54.2V	Jul 2018	-	07:34:37 07-27-2021
Deschutes	Line	120.0V 118.0V 129VA 52.9V	Mar 2010	-	07:08:37 07-27-2021
Dorris	Line	122.0V 121.0V 133VA 53.5V	Jan 2017	-	07:10:05 07-27-2021
Doyle	Line	121.0V 120.0V 192VA 53.0V	Jun 2019	-	07:34:37 07-27-2021
Dunsmuir	Line	119.0V 118.0V 129VA 53.6V	Feb 2016	-	07:31:39 07-27-2021
East_Riverside	Line	123.0V 121.0V 133VA 53.1V	Aug 2010	-	07:12:05 07-27-2021
EELab_1921	Line	116.0V 115.0V 195VA 54.4V	Nov 2014	-	07:31:35 07-27-2021
EELab_SNMP	Line	115.0V 114.0V 193VA 54.3V	Jan 2010	-	07:32:00 07-27-2021
Eureka_Way	Line	120.5V 120.0V 240VA 52.8V	Feb 2016	-	06:52:07 07-27-2021
Fawndale	Line	123.0V 121.0V 338VA 52.9V	Jun 2019	-	07:32:00 07-27-2021
Fredonver_Smt	Line	117.5V 117.0V 163VA 55.0V	Feb 2016	-	11:07:39 05-24-2021
! Gibson	Line	118.0V 117.0V 198VA 54.2V	Apr 2011	-	07:34:37 07-27-2021
Grass_Lake	Line	124.5V 124.0V 161VA 53.5V	Jul 2011	-	07:34:36 07-27-2021
Hartnell	Line	121.0V 120.0V 204VA 54.0V	Jan 2011	-	07:31:35 07-27-2021
Hatchet_Mtn	Line	122.5V 120.0V 180VA 53.4V	Jun 2019	-	07:35:36 07-27-2021
Hilltop	Line	121.0V 120.0V 168VA 52.9V	Oct 2017	-	07:31:35 07-27-2021
HilltopUPS	Line	121.0V 120.0V 168VA 52.9V	Oct 2017	-	07:36:00 07-27-2021
Hilt_Sandhouse	Line	122.0V 120.0V 192VA 52.7V	Jun 2019	-	07:17:09 07-27-2021
I5-SR273	Line	123.0V 121.0V 217VA 53.1V	Apr 2016	-	07:31:35 07-27-2021
I5-SR299	Line	122.0V 121.0V 205VA 53.9V	Sep 2016	-	07:34:35 07-27-2021
I5-SR44	Line	122.0V 120.0V 156VA 53.6V	Sep 2019	-	07:33:35 07-27-2021
I5-SR89	Line	121.0V 120.0V 144VA 53.8V	Apr 2013	-	07:27:58 07-27-2021
I5-US97	Line	121.0V 121.0V 157VA 54.1V	Sep 2012	-	07:25:38 07-27-2021
Janesville	Line	119.0V 117.0V 187VA 53.3V	Jun 2019	-	07:29:37 07-27-2021
Jellys_Ferry	Line	120.5V 119.0V 178VA 53.2V	Sep 2012	-	07:32:40 07-27-2021
Johnson_Grade	Line	121.0V 119.0V 130VA 53.4V	Jan 2011	-	07:31:08 07-27-2021
Johnson_Park	Line	120.0V 118.0V 141VA 53.1V	Jun 2019	-	07:27:32 07-27-2021
Lakehead	Line	122.0V 120.0V 252VA 54.4V	Nov 2011	-	07:31:35 07-27-2021
Lake_Blvd	Line	121.0V 119.0V 261VA 53.2V	Jun 2019	-	07:35:35 07-27-2021

Current Site Status

All Sites

Sites With Errors

Site	Current Mode	Power (kW)	Power (kVA)
Abrams_Lake	Line	120.0V	118.0V
Abrams_Lake_NB	Line	120.0V	118.0V
Abrams_Lake_SB	Line	122.0V	121.0V
Anderson_Grade	Line	117.0V	116.0V
! Antlers_Bridge	Line	119.0V	118.0V
Black_Butte	Line	120.5V	121.0V
Bogard	Line	122.5V	122.0V
! Bowman_Rd	Line	124.0V	123.0V
Buckhorn	Line	120.0V	119.0V
Cedar_Pass	Line	119.0V	118.0V
Central_Yreka	Line	119.0V	118.0V
Collier	Line	122.0V	121.0V
! Cottonwood_Truck_Scales	Line	124.0V	123.0V
Deschutes	Line	120.0V	119.0V
Dorris	Line	122.0V	121.0V
Doyle	Line	121.0V	120.0V
Dunsmuir	Line	119.0V	118.0V
East_Riverside	Line	123.0V	122.0V
EELab_1921	Line	116.0V	115.0V
EELab_SNMP	Line	115.0V	114.0V
Eureka_Way	Line	120.5V	120.0V
Fawndale	Line	123.0V	122.0V
Fredonver_Smt	Line	117.5V	116.5V
! Gibson	Line	118.0V	117.0V
Grass_Lake	Line	124.5V	123.5V
Hartnell	Line	121.0V	120.0V
Hatchet_Mtn	Line	122.5V	121.5V
Hilltop	Line	121.0V	120.0V
HilltopUPS	Line	121.0V	120.0V
Hilt_Sandhouse	Line	122.0V	121.0V
I5-SR273	Line	123.0V	122.0V
I5-SR299	Line	122.0V	121.0V
I5-SR44	Line	122.0V	121.0V
I5-SR89	Line	121.0V	120.0V
I5-US97	Line	121.0V	120.0V
Janesville	Line	119.0V	118.0V
Jellys_Ferry	Line	120.5V	119.5V
Johnson_Grade	Line	121.0V	120.0V
Johnson_Park	Line	120.0V	119.0V
Lakehead	Line	122.0V	121.0V
Lake_Blvd	Line	121.0V	120.0V

Site	Mode	V1	V2	V3	V4	Month	Days	Time
Lake_Blvd	Line	121.0V	119.0V	261VA	53.2V	Jun 2019	-	07:35:35 07-27-2021
Lake_BlvdUPS	Line	121.0V	119.0V	261VA	53.3V	Jun 2019	-	07:35:00 07-27-2021
Lassen_Park	Line	123.5V	124.0V	210VA	55.4V	Jun 2019	-	07:21:48 07-27-2021
La_Moine	Line	117.0V	116.0V	243VA	52.9V	Apr 2013	-	07:34:35 07-27-2021
Montgomery_Creek	Line	123.5V	122.0V	170VA	53.6V	Sep 2012	-	06:57:05 07-27-2021
! Mott_Rd	Line	119.0V	117.0V	81VA	53.1V	Sep 2019	-	07:06:39 07-27-2021
Mountain_Gate	Line	122.0V	121.0V	193VA	53.1V	Jul 2020	-	07:35:02 07-27-2021
! Mt_Hebron	Line	120.0V	119.0V	130VA	53.7V	Apr 2011	-	07:26:32 07-27-2021
North_Hilt	Line	124.0V	123.0V	159VA	53.5V	Sep 2012	-	07:33:35 07-27-2021
North_Mountain_Gate	Line	123.0V	122.0V	183VA	53.1V	Jul 2020	-	07:32:00 07-27-2021
North_Red_Bluff	Line	122.0V	121.0V	169VA	52.6V	Sep 2012	-	07:29:39 07-27-2021
North_Weed	Line	121.5V	121.0V	133VA	52.6V	Apr 2013	-	07:33:39 07-27-2021
O'Brien	Line	121.0V	119.0V	142VA	53.2V	Mar 2012	-	09:22:35 04-29-2020
! Oregon_Mtn	Line	120.0V	118.0V	200VA	53.1V	Jan 2017	-	07:35:13 07-27-2021
Perez	Line	119.0V	117.0V	163VA	53.2V	Sep 2012	-	07:31:35 07-27-2021
Pine_Grove	Line	120.0V	119.0V	226VA	36.2V	Jul 2018	-	07:33:36 07-27-2021
Pit_River_Bridge	Line	124.0V	123.0V	270VA	51.8V	Jun 2019	-	07:31:35 07-27-2021
! Pollard_Flat	Line	119.0V	117.0V	175VA	54.1V	Apr 2011	-	07:32:37 07-27-2021
Red_Bluff	Line	121.0V	119.0V	107VA	52.4V	Jul 2009	-	07:32:40 07-27-2021
Riverside_Ave	Line	118.5V	118.0V	153VA	52.4V	Apr 2016	-	07:34:35 07-27-2021
! Sacramento_Hill	Line	119.0V	111.0V	222VA	52.9V	Jun 2014	-	07:35:35 07-27-2021
Salt_Creek	Line	121.0V	119.0V	130VA	52.9V	Sep 2019	-	07:27:37 07-27-2021
Shasta_River_Bridge	Line	122.0V	121.0V	181VA	53.0V	Jul 2009	-	07:32:36 07-27-2021
Shingletown	Line	120.0V	120.0V	192VA	54.8V	Sep 2019	-	07:31:35 07-27-2021
Sidehill	Line	121.0V	120.0V	168VA	52.6V	Sep 2019	-	07:34:37 07-27-2021
Sims_Road	Line	119.0V	119.0V	154VA	54.9V	Sep 2012	-	07:35:39 07-27-2021
Smith_Rd	Line	122.0V	120.0V	168VA	54.2V	Jul 2017	-	07:31:35 07-27-2021
! Snowman	Line	121.0V	119.0V	154VA	53.5V	Apr 2013	-	07:33:36 07-27-2021
! South_Bonnyview	Line	119.0V	118.0V	177VA	53.5V	Nov 2008	-	07:35:36 07-27-2021
South_Weed	Line	125.0V	124.0V	99VA	52.9V	Jun 2019	-	06:53:39 07-27-2021
South_Yreka	Line	120.0V	118.0V	129VA	53.3V	Aug 2011	-	07:04:39 07-27-2021
Spring_Garden	Line	121.0V	119.0V	214VA	53.5V	Oct 2017	-	07:24:04 07-27-2021
SR299-SR89	Line	120.0V	119.0V	202VA	53.8V	Jun 2015	-	06:49:34 07-27-2021
! SR36-SR44	Line	124.5V	123.0V	221VA	53.8V	Apr 2011	-	06:52:34 07-27-2021
SR36-SR89	Line	121.0V	120.0V	192VA	54.3V	Apr 2011	-	07:34:35 07-27-2021
SR36-US395	Line	125.0V	124.0V	111VA	52.9V	Aug 2010	-	07:34:36 07-27-2021
SR70-SR89	Inverter	0.0V	120.0V	132VA	49.1V	Jun 2019	4 days, 14:39:06	23:57:08 07-22-2021
SR70-US395	Line	122.0V	122.0V	146VA	52.6V	Jan 2011	-	07:31:05 07-27-2021
Summit_Dr	Line	123.0V	122.0V	158VA	52.6V	Mar 2014	-	06:55:38 07-27-2021
Sundial_Bridge	Line	122.0V	121.0V	169VA	52.6V	Jan 2011	-	07:31:35 07-27-2021
! Townhill	Line	124.0V	123.0V	159VA	52.9V	Aug 2013	-	06:59:39 07-27-2021
Vina	Line	121.5V	122.0V	97VA	53.0V	Jun 2014	-	07:02:41 07-27-2021
Vollmers	Line	120.0V	119.0V	214VA	53.0V	Nov 2008	-	07:28:37 07-27-2021
Weed_Airport	Line	122.0V	120.0V	120VA	53.4V	Nov 2011	-	07:31:05 07-27-2021
Wilcox_Rd_NB	Line	121.0V	119.0V	178VA	52.5V	Jul 2016	-	07:14:39 07-27-2021
Wilcox_Rd_SB	Line	120.5V	119.0V	166VA	52.4V	Apr 2013	-	06:40:40 07-27-2021
Wonderland	Line	123.0V	121.0V	229VA	53.0V	Jul 2020	-	07:36:00 07-27-2021

87 Total Site(s) 2 Down Site(s) 1 Error Site(s) 13 Flagged Site(s) 0 Stale Site(s) 0 Site(s) Need Cert

Examples - Homepage

- First Example is of the system functioning normally

Current Site Status

All Sites

- On Inverter: ■
- On Buck/Boost: ■
- Data is stale (>2Hrs): ■
- Down for construction: ■
- Event Occurred Last 24Hrs: !

Sites With Errors

Site
Abrams_Lake
Abrams_Lake_NB
Abrams_Lake_SB
Anderson_Grade
! Antlers_Bridge
Black_Butte
Bogard
! Bowman_Rd
Buckhorn
Cedar_Pass
Central_Yreka
Collier
! Cottonwood_Truck_Stop

No Image
For This Site

Line	119.0V	118.0V	129VA	53.4V
Line	121.0V	117.0V	128VA	52.6V
Line	122.0V	120.0V	216VA	36.2V
Line	124.0V	122.0V	125VA	54.0V

New Site

ery Manufacture	Time in Error	Last Successful Pull
Jul 2018	-	07:35:35 07-27-2021
Apr 2016	-	07:34:36 07-27-2021
Jul 2018	-	07:35:35 07-27-2021
Sep 2019	-	07:32:08 07-27-2021
Jul 2009	-	07:35:35 07-27-2021
Apr 2016	-	07:22:35 07-27-2021
Sep 2019	-	07:33:04 07-27-2021
Sep 2012	-	06:57:37 07-27-2021
Dec 2006	-	07:24:39 07-27-2021
Mar 2012	-	07:04:09 07-27-2021
Feb 2016	-	07:36:38 07-27-2021
Dec 2018	-	07:08:43 07-27-2021
Jul 2018	-	07:34:27 07-27-2021

rally



Current Site Status

All Sites

- On Inverter: ■
- On Buck/Boost: ■
- Data is stale (>2Hrs): ■
- Down for construction: ■
- Event Occurred Last 24Hrs: !

Sites With Errors

New Site

Site	Line	Voltage	Current	Power	Frequency	Event Date	Time in Error	Last Successful Pull	
Abrams_Lake						Jul 2018	-	07:35:35 07-27-2021	
Abrams_Lake_NB						Apr 2016	-	07:34:36 07-27-2021	
Abrams_Lake_NB	Line	120.0V	118.0V	177VA	53.2V	Apr 2016	-	07:34:36 07-27-2021	
Anderson	Abrams_Lake_SB	Line	122.0V	120.0V	144VA	54.6V	Jul 2018	-	07:35:35 07-27-2021
Antlers_B	Anderson_Grade	Line	117.0V	116.0V	105VA	50.8V	Sep 2019	-	07:32:08 07-27-2021
Black_Butte	Antlers_Bridge					Jul 2009	-	07:35:35 07-27-2021	
Bogard	Black_Butte					Apr 2016	-	07:22:35 07-27-2021	
Bowman	Bogard					Sep 2019	-	07:33:04 07-27-2021	
Buckhorn	Bowman_Rd					Sep 2012	-	06:57:37 07-27-2021	
Cedar_Park	Buckhorn					Dec 2006	-	07:24:39 07-27-2021	
Central_Y									
Collier	East_Riverside	Line	123.0V	121.0V	133VA	53.1V	Aug 2010	-	07:12:05 07-27-2021
Cottonwood	EELab_1921	Line	118.0V	116.0V	105VA	51.4V	Nov 2014	-	07:31:35 07-27-2021
Collier	EELab_SNMP					Jan 2010	-	07:32:00 07-27-2021	
Cotton	Eureka_Way					Feb 2016	-	06:52:07 07-27-2021	
Desch	Fawndale					Jun 2019	-	07:37:00 07-27-2021	
Dorris	Fredonyer_Smt					Feb 2016	-	11:07:39 05-24-2021	
Doyle	Gibson					Apr 2011	-	07:34:37 07-27-2021	
Dunsmuir	Grass_Lake					Jul 2011	-	07:34:36 07-27-2021	
East_Lake	Hartnell					Jan 2011	-	07:36:35 07-27-2021	
EELat	Hatchet_Mtn					Jun 2019	-	07:35:36 07-27-2021	
EELat	Hilltop					Oct 2017	-	07:37:05 07-27-2021	
	HilltopUPS					Oct 2017	-	07:36:00 07-27-2021	
	Hilt_Sandhouse					Jun 2019	-	07:17:09 07-27-2021	
	I5-SR273					5 Apr 2016	-	07:36:35 07-27-2021	
	I5-SR299					Sep 2016	-	07:34:35 07-27-2021	
	I5-SR44	Line	122.0V	120.0V	156VA	53.6V	Sep 2019	-	07:33:35 07-27-2021
	I5-SR89	Line	121.0V	120.0V	144VA	53.8V	Apr 2013	-	07:27:58 07-27-2021

No Image



Down for Construction

Tuesday, July 27, 2021 07:37:01 PDT

Examples

- Next example is of the 2019 PG&E Power Safety Public Shutoff (PSPS)

Current Site Status

All Sites

Data is stale: ■
 Not in line state: ■
 Down for construction: ■
 Awaiting SSH certificate: ■
 Event Occurred Last 24Hrs: !

Sites With Error

New Site

Site	Firmware	Communication Type	Current Mode	Power (In, Out, Out, Batt)	Battery Install Date	Last Successful Pull
Abrams Lake NB	1.08.72	Cell	Line	121.0V 119.0V 154VA 55.0V	-	07:24:35 10-28-2019
Abrams Lake SB	2.00.01	Cell	Line	122.0V 121.0V 121VA 57.3V	-	07:20:35 10-28-2019
Anderson Grade	1.08.72	ISDN	Line	118.0V 117.0V 152VA 54.6V	-	04:02:08 10-28-2019
Antlers Bridge	1.08.72	MW	Inverter	0.0V 120.0V 228VA 42.6V	-	03:15:35 10-27-2019
Black Butte	1.08.72	Cell	Line	120.0V 118.0V 177VA 54.9V	-	07:22:35 10-28-2019
Boqard	1.08.72	POTS	Line	120.0V 120.0V 180VA 54.8V	-	07:18:03 10-28-2019
Bowman Rd	2.00.04	ISDN	Inverter	0.0V 120.0V 156VA 44.0V	-	10:58:05 10-27-2019
Buckhorn	2.00.04	ISDN	Line	116.0V 115.0V 103VA 56.7V	-	07:24:39 10-28-2019
Cedar Pass	1.08.72	POTS	Line	120.0V 120.0V 120VA 54.7V	-	07:04:10 10-28-2019
Central Yreka	1.08.72	ISDN	Line	118.5V 114.0V 114VA 54.8V	-	06:36:38 10-28-2019
Collier	1.08.72	ISDN	Line	121.0V 119.0V 202VA 55.5V	-	07:08:35 10-28-2019
Cottonwood Truck Scales	2.00.04	ISDN	Inverter	0.0V 120.0V 156VA 43.2V	-	13:34:37 10-27-2019
Deschutes	1.08.72	ISDN	Inverter	0.0V 120.0V 132VA 43.1V	-	08:08:37 10-27-2019
Dorris	1.08.72	POTS	Line	126.0V 125.0V 137VA 55.1V	-	07:10:05 10-28-2019
Dovle	2.00.01	Cell	Line	124.0V 124.0V 173VA 36.1V	-	07:24:36 10-28-2019
Dunsmuir	1.08.72	Cell	Line	119.5V 118.0V 118VA 54.9V	-	07:21:35 10-28-2019
East Riverside	1.08.72	POTS	Inverter	0.0V 120.0V 96VA 47.4V	-	07:12:03 10-28-2019
EELab 1921	2.01.00	POTS	Line	117.0V 116.0V 185VA 54.9V	May 2014	07:17:04 10-28-2019
EELab SNMP	2.01.00	POTS	Line	118.0V 117.0V 187VA 54.9V	Jan 2010	07:17:00 10-28-2019
Eureka Way	1.08.72	ISDN	Line	121.0V 120.0V 252VA 55.3V	-	06:51:50 10-28-2019
Fawndale	1.08.72	MW	Line	121.0V 119.0V 178VA 53.4V	-	13:12:30 05-29-2019
Fredonver Smt	1.08.72	Cell	Inverter	0.0V 120.0V 192VA 42.0V	-	06:12:36 10-28-2019
Gibson	2.00.04	ISDN	Line	117.0V 116.0V 197VA 56.5V	-	07:19:37 10-28-2019
Grass Lake	1.08.72	Cell	Line	122.5V 122.0V 134VA 54.8V	-	07:24:35 10-28-2019
Hartnell	1.08.72	FIBER	Line	121.0V 120.0V 168VA 54.5V	-	07:21:35 10-28-2019
Hatchet Mtn	1.08.72	Cell	Line	122.0V 120.0V 180VA 55.8V	-	07:20:36 10-28-2019
Hilltop	2.01.00	FIBER	Line	121.0V 120.0V 120VA 54.4V	-	07:21:35 10-28-2019
HilltopUPS	2.01.00	FIBER	Line	121.0V 120.0V 120VA 54.5V	-	07:21:00 10-28-2019
Hilt Sandhouse	2.00.04	ISDN	Line	122.0V 120.0V 132VA 55.5V	-	07:17:05 10-28-2019
I5-SR273	2.00.04	FIBER	Inverter	0.0V 120.0V 192VA 42.6V	-	05:51:35 10-27-2019
I5-SR299	2.00.04	FIBER	Line	121.0V 120.0V 180VA 55.5V	-	07:24:35 10-28-2019
I5-SR44	2.00.04	FIBER	Line	120.5V 119.0V 142VA 54.4V	-	07:23:35 10-28-2019
I5-SR89	1.08.72	ISDN	Line	120.0V 119.0V 142VA 54.7V	-	06:28:25 10-28-2019
I5-US97	2.00.04	ISDN	Line	119.0V 119.0V 154VA 56.8V	-	06:25:39 10-28-2019
Janesville	1.08.72	POTS	Line	121.5V 120.0V 180VA 38.1V	-	22:44:36 10-27-2019
Jellys Ferry	2.00.04	ISDN	Line	121.0V 119.0V 154VA 56.7V	-	06:32:40 10-28-2019
Johnson Grade	1.08.72	POTS	Inverter	0.0V 120.0V 132VA 48.1V	-	06:31:07 10-28-2019
Lakehead	1.08.72	MW	Inverter	0.0V 120.0V 240VA 42.5V	-	02:41:35 10-27-2019
Lake Blvd	2.01.00	MW	Line	122.0V 120.0V 228VA 54.6V	-	07:20:35 10-28-2019
Lake BlvdUPS	2.01.00	MW	Line	122.0V 120.0V 228VA 54.6V	-	07:20:01 10-28-2019
Lassen Park	1.08.72	POTS	Line	124.0V 124.0V 223VA 49.2V	-	17:21:33 10-26-2019
La Moine	1.08.72	MW	Line	116.0V 115.0V 230VA 54.6V	-	07:24:35 10-28-2019
Montgomery Creek	1.08.72	POTS	Inverter	0.0V 120.0V 156VA 43.0V	-	11:57:06 10-27-2019
Mott Rd	1.08.72	ISDN	Inverter	0.0V 120.0V 72VA 48.7V	-	09:06:55 05-28-2019
Mt Hebron	1.08.72	POTS	Line	117.5V 116.0V 116VA 54.6V	-	06:26:33 10-28-2019
North Hilt	1.08.72	Cell	Line	126.0V 124.0V 136VA 54.7V	-	07:23:35 10-28-2019
North Red Bluff	1.08.72	ISDN	Line	120.5V 120.0V 0VA 54.4V	-	06:29:40 10-28-2019
North Weed	1.08.72	ISDN	Line	119.0V 117.0V 128VA 54.7V	-	07:18:39 10-28-2019
O'Brien	1.08.72	MW	Inverter	0.0V 120.0V 192VA 42.2V	-	03:37:35 10-27-2019

Power Safety Public

Data is stale:

Not in line state:

Down for construction:

Apply CPU certificate:

Current Site Status

All Sites

Sites With Errors

Site	Firmware
Abrams Lake NB	1.08.72
Abrams Lake SB	2.00.01
Anderson Grade	1.08.72
Antlers Bridge	1.08.72
Black Butte	1.08.72
Bogard	1.08.72
Bowman Rd	2.00.04
Buckhorn	2.00.04
Cedar Pass	1.08.72
Central Yreka	1.08.72
Collier	1.08.72
Cottonwood Truck Scales	2.00.04
Deschutes	1.08.72
Dorris	1.08.72
Dovle	2.00.01
Dunsmuir	1.08.72
East Riverside	1.08.72
EELab 1921	2.01.00
EELab SNMP	2.01.00
Eureka Way	1.08.72
Fawndale	1.08.72
Fredonver Smt	1.08.72
Gibson	2.00.04
Grass Lake	1.08.72
Hartnell	1.08.72
Hatchet Mtn	1.08.72
Hilltop	2.01.00
HilltopUPS	2.01.00
Hilt Sandhouse	2.00.04
I5-SR273	2.00.04
I5-SR299	2.00.04
I5-SR44	2.00.04
I5-SR89	1.08.72
I5-US97	2.00.04
Janesville	1.08.72
Jellys Ferry	2.00.04
Johnson Grade	1.08.72
Lakehead	1.08.72
Lake Blvd	2.01.00
Lake BlvdUPS	2.01.00
Lassen Park	1.08.72
La Moine	1.08.72
Montgomery Creek	1.08.72
Mott Rd	1.08.72
Mt Hebron	1.08.72
North Hilt	1.08.72
North Red Bluff	1.08.72
North Weed	1.08.72
O'Brien	1.08.72

OBrien	1.08.72	MW	Inverter	0.0V	120.0V	192VA	42.2V	-	03:37:35	10-27-2019
Oregon Mtn	2.00.04	POTS	Line	125.5V	123.0V	184VA	55.4V	-	07:19:16	10-28-2019
Perez	1.08.72	MW	Line	117.5V	116.0V	162VA	55.1V	-	07:21:35	10-28-2019
Pine Grove	1.08.72	MW	Line	120.5V	120.0V	216VA	54.2V	-	07:23:36	10-28-2019
Pit River Bridge	1.08.72	MW	Inverter	0.0V	120.0V	252VA	42.0V	Jun 2019	05:01:35	10-27-2019
Pollard Flat	2.00.04	ISDN	Line	119.0V	118.0V	177VA	56.0V	-	07:17:37	10-28-2019
Red Bluff	1.08.72	ISDN	Line	121.0V	119.0V	119VA	53.3V	-	07:17:35	10-28-2019
Riverside Ave	1.08.72	FIBER	Line	119.0V	118.0V	153VA	54.5V	-	07:24:35	10-28-2019
Sacramento Hill	1.08.72	MW	Inverter	0.0V	120.0V	216VA	42.3V	-	04:55:35	10-27-2019
Salt Creek	1.08.72	ISDN	Inverter	0.0V	120.0V	132VA	45.3V	-	19:27:37	10-26-2019
Shasta River Bridge	1.08.72	Cell	Line	119.0V	118.0V	165VA	54.7V	-	07:17:36	10-28-2019
Shingletown	1.08.72	POTS	Line	121.0V	121.0V	205VA	51.8V	-	18:01:37	10-26-2019
Sidehill	1.08.72	ISDN	Inverter	0.0V	120.0V	132VA	42.2V	-	19:49:32	06-25-2019
Sims Road	1.08.72	ISDN	Line	118.0V	118.0V	129VA	55.1V	-	07:20:38	10-28-2019
Smith Rd	2.00.04	FIBER	Line	121.0V	119.0V	119VA	55.5V	-	07:21:35	10-28-2019
Snowman	1.08.72	Cell	Line	119.0V	117.0V	117VA	54.8V	-	07:23:35	10-28-2019
South Bonnvievw	2.00.04	FIBER	Line	119.0V	117.0V	152VA	55.5V	-	07:20:35	10-28-2019
South Weed	1.08.72	ISDN	Line	124.0V	123.0V	123VA	49.3V	-	06:53:39	10-28-2019
South Yreka	1.08.72	ISDN	Line	121.5V	120.0V	108VA	56.0V	-	07:04:38	10-28-2019
Spring Garden	1.08.72	POTS	Line	124.5V	125.0V	200VA	56.2V	-	07:24:04	10-28-2019
SR299-SR89	1.08.72	POTS	Line	117.0V	116.0V	150VA	54.9V	-	06:49:38	10-28-2019
SR36-SR44	1.08.72	POTS	Line	125.0V	124.0V	136VA	55.1V	-	21:52:03	10-27-2019
SR36-SR89	1.08.72	MW	Inverter	0.0V	120.0V	168VA	47.1V	-	07:24:37	10-28-2019
SR36-US395	1.08.72	POTS	Inverter	0.0V	120.0V	108VA	47.8V	-	07:24:36	10-28-2019
SR70-SR89	1.08.72	POTS	Inverter	0.0V	120.0V	120VA	44.8V	-	02:56:06	10-28-2019
SR70-US395	1.08.72	POTS	Line	118.5V	118.0V	177VA	55.1V	-	07:01:06	10-28-2019
Summit Dr	1.08.72	ISDN	Line	120.0V	119.0V	130VA	54.9V	-	06:56:20	10-28-2019
Sundial Bridge	1.08.72	FIBER	Line	123.0V	121.0V	157VA	54.1V	-	07:21:35	10-28-2019
Townhill	1.08.72	POTS	Inverter	0.0V	120.0V	132VA	44.3V	-	04:59:35	10-28-2019
Vina	1.08.72	ISDN	Inverter	0.0V	120.0V	108VA	43.9V	-	18:02:40	10-27-2019
Vollmers	1.08.72	ISDN	Line	119.0V	117.0V	198VA	54.3V	-	07:13:37	10-28-2019
Weed Airport	1.08.72	ISDN	Line	121.0V	119.0V	130VA	54.7V	-	07:15:35	10-28-2019
Wilcox Rd NB	1.08.72	ISDN	Line	123.0V	122.0V	170VA	55.3V	-	07:14:40	10-28-2019
Wilcox Rd SB	1.08.72	ISDN	Line	123.0V	121.0V	157VA	54.7V	-	06:40:39	10-28-2019

82 Total Site(s) 3 Down Site(s) 19 Error Site(s) 23 Flagged Site(s) 5 Stale Site(s) 0 Site(s) Need Cert

Examples – Error Sites

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Powered By D2 ITS

Current Site Status

All Sites

On Inverter: ■

On Buck/Boost: ■

Data is stale (>2Hrs): ■

Down for construction: ■

Event Occurred Last 24Hrs: !

Sites With Errors

[New Site](#)

Site	Current Mode	Power (In, Out, Out, Batt)	Battery Manufacture	Time in Error	Last Successful Pull
Abrams_Lake	Line	120.0V 119.0V 202VA 54.8V	Jul 2018	-	07:30:35 07-27-2021
Abrams_Lake_NB	Line	120.0V 118.0V 177VA 53.2V	Apr 2016	-	07:29:36 07-27-2021
Abrams Lake SB	Line	121.0V 120.0V 144VA 54.6V	Jul 2018	-	07:30:35 07-27-2021



[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Powered By D2 ITS

Current Site Status

All Sites

On Inverter: ■

On Buck/Boost: ■

Data is stale (>2Hrs): ■

Down for construction: ■

Event Occurred Last 24Hrs: !

All Sites

[New Site](#)

Site	Current Mode	Power (In, Out, Out, Batt)	Battery Manufacture	Time in Error	Last Successful Pull
Fredonyer_Smt	Line	117.5V 117.0V 163VA 55.0V	Feb 2016	-	11:07:39 05-24-2021
OBrien	Line	121.0V 119.0V 142VA 53.2V	Mar 2012	-	09:22:35 04-29-2020
SR70-SR89	Inverter	0.0V 120.0V 132VA 49.1V	Jun 2019	4 days, 14:36:38	23:57:08 07-22-2021

3 Total Site(s) 2 Down Site(s) 1 Error Site(s) 0 Flagged Site(s) 0 Stale Site(s) 0 Site(s) Need Cert

Powered By D2 ITS - [Contributors](#)


Examples – Event Data (No Recent)


[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)


Powered By D2 ITS


Current Site Status


All Sites

On Inverter: 

On Buck/Boost: 

Data is stale (>2Hrs): 

Down for construction: 

Event Occurred Last 24Hrs: 

[Sites With Errors](#)

[New Site](#)

Site	Current Mode	Power (In, Out, Out, Batt)	Battery Manufacture	Time in Error	Last Successful Pull
Abrams Lake	Line	120.0V 119.0V 202VA 54.8V	Jul 2018	-	07:30:35 07-27-2021
Abrams Lake NB	Line	120.0V 118.0V 177VA 53.2V	Apr 2016	-	07:29:36 07-27-2021
Abrams Lake SB	Line	121.0V 120.0V 144VA 54.6V	Jul 2018	-	07:30:35 07-27-2021

Examples – Event Data (No Recent)

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Powered By D2 ITS

Total Events: 16

Not on Line: 9

Number of alarms: 6

Number of faults: 0

Abrams Lake NB

Last 30 Days

[Edit Site](#) | [Archive](#) | [Inverter Events](#) | [Logs](#) | [Power](#)

[Last 24 Hours](#) | [Last 48 Hours](#) | [Last 30 Days](#) | [Last Year](#)

Date Time	Mode	Alarms	Faults	Data Retrieved Time
07-11-2021 22:06:05	Line	0000000000000000	0000000000000000	07-11-2021 22:05:06
07-11-2021 22:05:58	Inverter	0000000000000000	0000000000000000	07-11-2021 22:05:06
07-04-2021 22:56:13	Line	0000000000000000	0000000000000000	07-04-2021 22:54:36
07-04-2021 22:55:12	Boost1	0000000000000000	0000000000000000	07-04-2021 22:54:36
07-04-2021 22:55:07	Line	0000000000000000	0000000000000000	07-04-2021 22:54:36
07-04-2021 22:55:01	Line	1000000000000000	0000000000000000	07-04-2021 22:54:36
07-04-2021 20:23:53	Inverter	1000000000000000	0000000000000000	07-04-2021 20:24:36
07-04-2021 20:22:50	Inverter	0000000000000000	0000000000000000	07-04-2021 20:24:36
06-30-2021 13:54:40	Line	0000000000000000	0000000000000000	06-30-2021 13:54:35
06-30-2021 13:54:35	Line	1000000000000000	0000000000000000	06-30-2021 13:54:35
06-30-2021 13:54:30	Inverter	1000000000000000	0000000000000000	06-30-2021 13:54:35
06-30-2021 13:50:39	Inverter	10000001000000	0000000000000000	06-30-2021 13:49:36
06-30-2021 13:49:37	Inverter	00000001000000	0000000000000000	06-30-2021 13:49:36
06-30-2021 13:49:36	Inverter	0000000000000000	0000000000000000	06-30-2021 13:49:36
06-30-2021 10:47:02	Line	0000000000000000	0000000000000000	06-30-2021 10:49:36
06-30-2021 10:46:56	Inverter	0000000000000000	0000000000000000	06-30-2021 10:49:36

Powered By D2 ITS - [Contributors](#)

Last 30 Days

Examples – Event Data (Alarms)

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Powered By D2 ITS

Abrams Lake NB Last 30 Days

Total Events: 16

Not on Line: 9

Number of alarms: 6

Number of faults: 0

[Edit Site](#) | [Archive](#) | [Inverter Events](#) | [Logs](#) | [Power](#)

[Last 24 Hours](#) | [Last 48 Hours](#) | [Last 30 Days](#) | [Last Year](#)

Date Time	Mode	Alarms	Faults	Data Retrieved Time
07-11-2021 22:06:05	Line	0000000000000000	0000000000000000	07-11-2021 22:05:06
07-11-2021 22:05:58	Inverter	0000000000000000	0000000000000000	07-11-2021 22:05:06
07-04-2021 22:56:13	Line	0000000000000000	0000000000000000	07-04-2021 22:54:36
07-04-2021 22:55:12	Boost1	0000000000000000	0000000000000000	07-04-2021 22:54:36
07-04-2021 22:55:07	Line	0000000000000000	0000000000000000	07-04-2021 22:54:36
07-04-2021 22:55:01	Line	1000000000000000	0000000000000000	07-04-2021 22:54:36
07-04-2021 20:23:53	Inverter	1000000000000000	0000000000000000	07-04-2021 20:24:36
07-04-2021 20:22:50	Inverter	0000000000000000	0000000000000000	07-04-2021 20:24:36
06-30-2021 13:54:40	Line	0000000000000000	0000000000000000	06-30-2021 13:54:35
06-30-2021 13:54:35	Line	1000000000000000	0000000000000000	06-30-2021 13:54:35
06-30-2021 13:54:30	Inverter	1000000000000000	0000000000000000	06-30-2021 13:54:35
06-30-2021 13:50:39	Inverter	1000000010000000	0000000000000000	06-30-2021 13:49:36
06-30-2021 13:49:37	Inverter	0000000010000000	0000000000000000	06-30-2021 13:49:36
06-30-2021 13:49:36	Inverter	000000 ['Power Outage', 'Input Frequency Out of Range']		06-30-2021 13:49:36
06-30-2021 10:47:02	Line	0000000000000000	0000000000000000	06-30-2021 10:49:36
06-30-2021 10:46:56	Inverter	0000000000000000	0000000000000000	06-30-2021 10:49:36

Powered By D2 ITS - Contributors

Examples – Event Data (Recent)

<u>North Hill</u>	Line	123.0V	121.0V	157VA	54.2V	Sep 2012	-	10:48:36 07-27-2021
<u>North Mountain Gate</u>	Line	124.0V	122.0V	183VA	53.1V	Jul 2020	-	10:47:00 07-27-2021
<u>North Red Bluff</u>	Line	123.0V	121.0V	181VA	52.4V	Sep 2012	-	10:29:39 07-27-2021
<u>North Weed</u>	Line	123.0V	122.0V	134VA	54.1V	Apr 2013	-	10:48:38 07-27-2021
<u>OBrien</u>	Line	121.0V	119.0V	142VA	53.2V	Mar 2012	-	09:22:35 04-29-2020
<u>Oregon Mtn</u>	Line	119.0V	117.0V	198VA	53.0V	Jan 2017	-	10:49:16 07-27-2021
<u>Perez</u>	Line	119.0V	117.0V	163VA	52.9V	Sep 2012	-	10:46:35 07-27-2021
<u>Pine Grove</u>	Line	121.0V	119.0V	226VA	36.2V	Jul 2018	-	10:49:06 07-27-2021

Total Events: 64

Not on Line: 42

Number of alarms: 11

Number of faults: 0

Oregon Mtn

Last 24 Hours

Last 24 Hrs.

[Edit Site](#) | [Archive](#) | [Inverter Events](#) | [Logs](#) | [Power](#)

[Last 24 Hours](#) | [Last 48 Hours](#) | [Last 30 Days](#) | [Last Year](#)

Date Time	Mode	Alarms	Faults	Data Retrieved Time
07-27-2021 10:27:05	Line	0000000000000000	0000000000000000	07-27-2021 10:34:03
07-27-2021 10:26:53	Inverter	0000000000000000	0000000000000000	07-27-2021 10:34:03
07-27-2021 10:26:53	Inverter	0000000010000000	0000000000000000	07-27-2021 10:34:03
07-27-2021 08:40:07	Line	0000000000000000	0000000000000000	07-27-2021 08:49:08
07-27-2021 08:39:54	Inverter	0000000000000000	0000000000000000	07-27-2021 08:49:08
07-27-2021 08:39:54	Inverter	0000000010000000	0000000000000000	07-27-2021 08:49:08
07-27-2021 08:22:11	Line	0000000000000000	0000000000000000	07-27-2021 08:34:09
07-27-2021 08:21:59	Inverter	00000000 ['Input Frequency Out of Range']	0000000000	07-27-2021 08:34:09
07-27-2021 08:21:58	Inverter	0000000000000000	0000000000000000	07-27-2021 08:34:09
07-27-2021 06:43:14	Line	0000000000000000	0000000000000000	07-27-2021 06:49:13
07-27-2021 06:43:08	Line	0000000000000000	0000000000000000	07-27-2021 06:49:13
07-27-2021 06:43:08	Inverter	0000000000000000	0000000000000000	07-27-2021 06:49:13
07-27-2021 06:43:01	Inverter	0000000000000000	0000000000000000	07-27-2021 06:49:13
07-27-2021 06:25:25	Line	0000000000000000	0000000000000000	07-27-2021 06:34:09
07-27-2021 06:25:18	Line	0000000000000000	0000000000000000	07-27-2021 06:34:09
07-27-2021 06:25:18	Inverter	0000000000000000	0000000000000000	07-27-2021 06:34:09
07-27-2021 06:25:12	Inverter	0000000000000000	0000000000000000	07-27-2021 06:34:09
07-27-2021 04:26:12	Line	0000000000000000	0000000000000000	07-27-2021 04:35:15
07-27-2021 04:26:05	Line	0000000000000000	0000000000000000	07-27-2021 04:35:15
07-27-2021 04:26:05	Inverter	0000000000000000	0000000000000000	07-27-2021 04:35:15
07-27-2021 04:25:59	Inverter	0000000000000000	0000000000000000	07-27-2021 04:35:15
07-27-2021 02:42:48	Line	0000000000000000	0000000000000000	07-27-2021 02:49:08
07-27-2021 02:42:42	Line	0000000000000000	0000000000000000	07-27-2021 02:49:08
07-27-2021 02:42:42	Inverter	0000000000000000	0000000000000000	07-27-2021 02:49:08
07-27-2021 02:42:35	Inverter	0000000000000000	0000000000000000	07-27-2021 02:49:08
07-27-2021 01:17:48	Line	0000000000000000	0000000000000000	07-27-2021 01:19:13
07-27-2021 01:17:41	Inverter	0000000000000000	0000000000000000	07-27-2021 01:19:13
07-27-2021 00:24:02	Line	0000000000000000	0000000000000000	07-27-2021 00:34:10
07-27-2021 00:23:55	Inverter	0000000000000000	0000000000000000	07-27-2021 00:34:10
07-27-2021 00:23:55	Boost1	0000000000000000	0000000000000000	07-27-2021 00:34:10
07-27-2021 00:23:55	Line	0000000000000000	0000000000000000	07-27-2021 00:34:10
07-27-2021 00:23:48	Inverter	0000000000000000	0000000000000000	07-27-2021 00:34:10
07-26-2021 22:22:53	Line	0000000000000000	0000000000000000	07-26-2021 22:34:15

Examples – Event Data (No Power 4+ Days)

! SR36-SR44	Line	125.0V	124.0V	223VA	52.9V	Apr 2011	-	09:52:45 07-27-2021
SR36-SR89	Line	121.0V	120.0V	192VA	53.2V	Apr 2011	-	10:49:36 07-27-2021
SR36-US395	Line	125.0V	125.0V	112VA	52.9V	Aug 2010	-	10:49:36 07-27-2021
SR70-SR89	Inverter	0.0V	120.0V	132VA	49.1V	Jun 2019	4 days, 17:54:16	23:57:08 07-22-2021
SR70-US395	Line	122.5V	122.0V	146VA	52.7V	Jan 2011	-	10:46:05 07-27-2021
Summit_Dr	Line	123.0V	122.0V	158VA	52.6V	Mar 2014	-	09:55:38 07-27-2021

SR70-SR89

Last 30 Days

Total Events: 38

Not on Line: 21

Number of alarms: 1

Number of faults: 0

[Edit Site](#) | [Archive](#) | [Inverter Events](#) | [Logs](#) | [Power](#)

[Last 24 Hours](#) | [Last 48 Hours](#) | [Last 30 Days](#) | [Last Year](#)

Date Time	Mode	Alarms	Faults	Data Retrieved Time
07-22-2021 18:05:13	Inverter	0000000000000000	0000000000000000	07-22-2021 18:56:15
07-22-2021 17:56:13	Line	0000000000000000	0000000000000000	07-22-2021 18:56:15
07-22-2021 17:56:07	Boost1	0000000000000000	0000000000000000	07-22-2021 20:56:05
07-22-2021 17:56:07	Inverter	0000000000000000	0000000000000000	07-22-2021 18:56:15
07-22-2021 16:54:50	Line	0000000000000000	0000000000000000	07-22-2021 20:56:05
07-22-2021 16:54:43	Inverter	0000000000000000	0000000000000000	07-22-2021 20:56:05
07-22-2021 16:53:22	Line	0000000000000000	0000000000000000	07-22-2021 20:56:05
07-22-2021 16:53:15	Inverter	0000000000000000	0000000000000000	07-22-2021 20:56:05
07-22-2021 12:30:46	Line	0000000000000000	0000000000000000	07-22-2021 12:56:05
07-22-2021 12:30:39	Inverter	0000000000000000	0000000000000000	07-22-2021 12:56:05
07-21-2021 16:41:45	Line	0000000000000000	0000000000000000	07-21-2021 16:56:05
07-21-2021 16:41:38	Inverter	0000000000000000	0000000000000000	07-21-2021 16:56:05
07-21-2021 16:39:10	Line	0000000000000000	0000000000000000	07-21-2021 16:56:05
07-21-2021 16:10:09	Inverter	0000000000000000	0000000000000000	07-21-2021 16:56:05
07-21-2021 15:34:11	Line	0000000000000000	0000000000000000	07-21-2021 15:56:04
07-21-2021 15:34:04	Inverter	0000000000000000	0000000000000000	07-21-2021 15:56:04
07-19-2021 18:11:44	Line	0000000000000000	0000000000000000	07-19-2021 18:57:10
07-19-2021 18:11:44	Boost1	0000000000000000	0000000000000000	07-19-2021 18:57:10
07-19-2021 18:04:03	Line	0000000000000000	0000000000000000	07-19-2021 18:57:10
07-19-2021 14:38:31	Inverter	0000000000000000	0000000000000000	07-19-2021 14:56:36
07-17-2021 12:20:20	Line	0000000000000000	0000000000000000	07-17-2021 12:57:05
07-17-2021 12:20:13	Inverter	0000000000000000	0000000000000000	07-17-2021 12:57:05
07-16-2021 14:14:09	Line	0000000000000000	0000000000000000	07-16-2021 14:56:11
07-16-2021 14:14:03	Inverter	0000000000000000	0000000000000000	07-16-2021 14:56:11
07-14-2021 14:03:17	Line	0000000000000000	0000000000000000	07-14-2021 14:56:05
07-14-2021 14:03:10	Inverter	0000000000000000	0000000000000000	07-14-2021 14:56:05
07-14-2021 13:19:52	Line	0000000000000000	0000000000000000	07-14-2021 13:56:05
07-14-2021 13:19:47	Inverter	0000000100000000	0000000000000000	07-14-2021 13:56:05
07-14-2021 13:19:47	Inverter	0000000000000000	0000000000000000	07-14-2021 13:56:05
07-14-2021 11:01:43	Inverter	0000000000000000	0000000000000000	07-14-2021 11:56:03
07-13-2021 12:15:34	Line	0000000000000000	0000000000000000	07-13-2021 12:57:11
07-13-2021 12:15:27	Inverter	0000000000000000	0000000000000000	07-13-2021 12:57:11
07-09-2021 12:15:33	Line	0000000000000000	0000000000000000	07-09-2021 12:57:01
07-09-2021 12:15:27	Inverter	0000000000000000	0000000000000000	07-09-2021 12:57:01
07-03-2021 12:15:26	Line	0000000000000000	0000000000000000	07-03-2021 12:56:04
07-03-2021 12:15:19	Inverter	0000000000000000	0000000000000000	07-03-2021 12:56:04
06-30-2021 12:15:26	Line	0000000000000000	0000000000000000	06-30-2021 12:56:04
06-30-2021 12:15:19	Inverter	0000000000000000	0000000000000000	06-30-2021 12:56:04

- [! SR36-](#)
- [SR36-](#)
- [SR36-](#)
- [SR70-](#)
- [SR70-](#)
- [Summ](#)

- [7-2021](#)
- [7-2021](#)
- [7-2021](#)
- [2-2021](#)
- [7-2021](#)
- [7-2021](#)

Examples - Power

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Abrams Lake NB

Last 30 Days

[Edit Site](#) | [Archive](#) | [Inverter Events](#) | [Logs](#) | [Power](#)

Date Time	Mode	
07-11-2021 22:06:05	Line	000
07-11-2021 22:05:58	Inverter	000
07-04-2021 22:56:13	Line	000
07-04-2021 22:55:12	Boost1	000

Examples - Power

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Abrams Lake NB Last 30 Days

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Powered By D2 PPS


Abrams Lake NB Power Stats

Graph last 3 day(s)


[View Table](#) | [View Events](#)

[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)


[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)




Examples - Power



Examples - Power




Examples - Power



Examples - Power

Greater than 3 days only shows Min/Max per day

Graph last 30 day(s)



Examples - Power

Abrams Lake NB Power Stats

Graph last 30 day(s)

[View Table](#) | [View Events](#)

[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)

[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Abrams_Lake_NB

Date Range Selection

Select Start Date:

Select End Date:

Table

Graph

Back

Examples - Power

Abrams Lake NB Power Stats

Graph last 30 day(s)

[View Table](#) | [View Events](#)

[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)

[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)


Abrams_Lake_NB

Graph 07-08-2021 to 07-22-2021

[View Table](#) | [View Events](#)

[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)

[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)



Examples - Power

All Graphs Input Output | Battery


Examples - Power

All Graphs **Input** Output | Battery

Abrams Lake NB Power Stats

Graph last 3 day(s)

[View Table](#) | [View Events](#) [All Graphs](#) | [Input](#) | [Output](#) | [Battery](#) [Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)



Input Voltage for last 3 day(s)

Examples - Power

All Graphs **Input** Output | Battery


Abrams Lake NB Power Stats

Graph last 3 day(s)

[View Table](#) | [View Events](#)

[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)

[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)




Examples - Power

All Graphs | Input **Output** | Battery


Examples - Power

All Graphs | Input **Output** Battery




Examples - Power

All Graphs | Input **Output** | Battery



Examples - Power

All Graphs | Input **Output** | Battery




Examples - Power

All Graphs | [Input](#) | [Output](#) | [Battery](#)



Examples - Power

All Graphs | Input | Output | **Battery**



Examples - Power

[All Graphs](#) | [Input](#) | [Output](#) | **Battery**



Examples - Power

Abrams Lake NB Power Stats

Graph last 3 day(s)

[View Table](#) | [View Events](#)

Abrams Lake NB Power Stats

Table last 3 day(s)

[CSV Download](#) | [Power Graphical](#)

Date Range Selector | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)

Date Time	Input Voltage (V)	Input Frequency (Hz)	Output Voltage (V)	Output Current (A)	Output Power (VA)	Battery Voltage (V)	Battery Temperature (°C)	Mode
2021-07-27 10:39:36	121.0	59.9	119.0	1.5	178	53.3	23	Line
2021-07-27 10:30:06	120.5	59.9	119.0	1.5	178	53.2	23	Line
2021-07-27 10:24:36	121.0	59.9	119.0	1.5	178	53.2	23	Line
2021-07-27 10:19:35	121.0	59.9	119.0	1.5	178	53.3	23	Line
2021-07-27 10:14:36	121.0	59.9	119.0	1.5	178	53.2	23	Line
2021-07-27 10:09:36	121.0	60.0	119.0	1.5	178	53.2	23	Line
2021-07-27 10:04:35	121.0	59.9	119.0	1.5	178	53.3	23	Line
2021-07-27 09:59:36	120.0	60.0	119.0	1.5	178	53.3	23	Line
2021-07-27 09:54:35	120.0	60.0	118.0	1.5	177	53.3	23	Line
2021-07-27 09:49:36	120.5	60.0	119.0	1.5	178	53.3	23	Line
2021-07-27 09:45:06	121.0	59.9	119.0	1.5	178	53.3	23	Line
2021-07-27 09:39:35	121.0	59.9	120.0	1.5	180	53.2	23	Line
2021-07-27 09:34:37	120.5	59.9	119.0	1.5	178	53.3	23	Line
2021-07-27 09:29:36	121.0	59.9	119.0	1.5	178	53.2	23	Line
2021-07-27 09:24:35	121.0	59.9	119.0	1.5	178	53.2	23	Line
2021-07-27 09:19:36	120.0	59.9	118.0	1.5	177	53.2	23	Line
2021-07-27 09:14:35	121.0	59.9	119.0	1.5	178	53.2	23	Line
2021-07-27 09:09:36	120.0	59.9	118.0	1.5	177	53.2	23	Line
2021-07-27 09:04:36	121.0	60.0	119.0	1.5	178	53.2	23	Line
2021-07-27 08:59:35	121.0	59.9	119.0	1.5	178	53.2	23	Line
2021-07-27 08:54:36	120.0	59.9	118.0	1.5	177	53.2	23	Line

Examples - Power

Abrams Lake NB Power Stats

Graph last 3 day(s)

[View Table](#) [View Events](#)


Examples - Power

Abrams Lake NB Power Stats

Table last 3 day(s)

[CSV Download](#) [Power Graphical](#)

Date Time	Input Voltage (V)	Input Frequency (Hz)	Output Voltage (V)
2021-07-27 10:39:36	121.0	59.9	119.0
2021-07-27 10:20:08	120.5	59.9	119.0



Examples – Power (Outage)

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Powered By D2 ITS

Total Events: 38

Not on Line: 21

Number of alarms: 1

Number of faults: 0

SR70-SR89

Last 30 Days

[Edit Site](#) | [Archive](#) | [Inverter Events](#) | [Logs](#) | [Power](#)

[Last 24 Hours](#) | [Last 48 Hours](#) | [Last 30 Days](#) | [Last Year](#)

Date Time	Mode	Alarms	Faults	Data Retrieved Time
07-22-2021 18:05:13	Inverter	0000000000000000	0000000000000000	07-22-2021 18:56:15
07-22-2021 17:56:13	Line	0000000000000000	0000000000000000	07-22-2021 18:56:15
07-22-2021 17:56:07	Boost1	0000000000000000	0000000000000000	07-22-2021 20:56:05
07-22-2021 17:56:07	Inverter	0000000000000000	0000000000000000	07-22-2021 18:56:15
07-22-2021 16:54:50	Line	0000000000000000	0000000000000000	07-22-2021 20:56:05
07-22-2021 16:54:43	Inverter	0000000000000000	0000000000000000	07-22-2021 20:56:05

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

SR70-SR89 Power Stats

No Data Available for the last last 3 day(s)

[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)

[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)

[View Table](#) | [View Events](#)

Script complete time 0.82808804512

SQL retrieval time 0.827903985977

Total Data Points 1

Powered By D2 ITS - [Contributors](#)

Examples – Power (Outage)


SR70-SR89 Power Stats

Graph last 30 day(s)

[View Table](#) | [View Events](#)

[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)


[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)



Examples – Power (Outage)



- Graph page of a site running off battery backup with no input power

Examples – Power (Outage)



ing off battery backup with no

Examples – Power (Outage)



Examples – Inverter Events

Home [Inverter Events](#) [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Inverter Events

All Sites

Filename	Size	Created
Abrams_Lake_NB_events.txt	2192 Bytes	2021-07-27 07:44:16
Abrams_Lake_SB_events.txt	2192 Bytes	2021-07-27 07:45:14
Abrams_Lake_events.txt	2192 Bytes	2021-07-27 07:45:18
Anderson_Grade_events.txt	2192 Bytes	2021-07-27 07:46:40
Antlers_Bridge_events.txt	2192 Bytes	2021-07-27 07:45:14
Black_Butte_events.txt	2192 Bytes	2021-07-27 07:45:14
Bogard_events.txt	560 Bytes	2021-07-27 07:47:39
Bowman_Rd_events.txt	1389 Bytes	2021-07-27 06:57:32
Buckhorn_events.txt	1259 Bytes	2021-07-27 07:39:34
Cedar_Pass_events.txt	1234 Bytes	2021-07-27 07:04:03
Central_Yreka_events.txt	1150 Bytes	2021-07-27 07:36:33
Collier_events.txt	2192 Bytes	2021-07-27 07:08:28
Cottonwood_Truck_Scales_events.txt	1328 Bytes	2021-07-27 07:34:32
Deschutes_events.txt	1401 Bytes	2021-07-27 07:08:32
Dorris_events.txt	815 Bytes	2021-07-27 07:39:57
Doyle_events.txt	2192 Bytes	2021-07-27 07:44:23
Dunsmuir_events.txt	1229 Bytes	2021-07-27 07:46:34
EELab_1921_events.txt	890 Bytes	2021-07-27 07:46:30
East_Riverside_events.txt	2192 Bytes	2021-07-27 07:11:58
Eureka_Way_events.txt	2192 Bytes	2021-07-27 06:51:36
Fawndale_events.txt	2192 Bytes	2020-10-06 13:47:12
Fredonyer_Smt_events.txt	2191 Bytes	2021-05-24 11:07:16
Gibson_events.txt	1210 Bytes	2021-07-27 07:34:00

Complete
Download of site
events

Partial Download
of site events

Examples – Inverter Events

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Inverter Events

All Sites

Filename	Size	Last Modified
Abrams_Lake_NB_events.txt	2192 Bytes	2021-07-27 07:44:16
Abrams_Lake_SB_events.txt	2192 Bytes	2021-07-27 07:45:14
Abrams_Lake_events.txt	2192 Bytes	2021-07-27 07:45:18
Anderson_Grade_events.txt	2192 Bytes	2021-07-27 07:46:40
Antlers_Bridge_events.txt	2192 Bytes	2021-07-27 07:45:14
Black_Butte_events.txt	2192 Bytes	2021-07-27 07:37:16
Bogard_events.txt	560 Bytes	2021-07-27 07:47:39
Bowman_Rd_events.txt	1389 Bytes	2021-07-27 06:57:32
Buckhorn_events.txt	1259 Bytes	2021-07-27 07:39:34
Cedar_Pass_events.txt	1234 Bytes	2021-07-27 07:04:03
Central_Yreka_events.txt	1150 Bytes	2021-07-27 07:36:33
Collier_events.txt	2192 Bytes	2021-07-27 07:08:28
Cottonwood_Truck_Scales_events.txt	1328 Bytes	2021-07-27 07:34:32
Deschutes_events.txt	1401 Bytes	2021-07-27 07:08:32
Dorris_events.txt	815 Bytes	2021-07-27 07:39:57
Doyle_events.txt	2192 Bytes	2021-07-27 07:44:23
Dunsmuir_events.txt	1229 Bytes	2021-07-27 07:46:34
EELab_1921_events.txt	890 Bytes	2021-07-27 07:46:30
East_Riverside_events.txt	2192 Bytes	2021-07-27 07:11:58
Eureka_Way_events.txt	2192 Bytes	2021-07-27 06:51:36
Fawndale_events.txt	2192 Bytes	2020-10-06 13:47:12
Fredonyer_Smt_events.txt	2191 Bytes	2021-05-24 11:07:16
Gibson_events.txt	1210 Bytes	2021-07-27 07:34:00

Exam

ents

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site L](#)

Inverter Events

All Sites

Filename
Abrams_Lake_NB_events.txt
Abrams_Lake_SB_events.txt
Abrams_Lake_events.txt
Anderson_Grade_events.txt
Antlers_Bridge_events.txt
Black_Butte_events.txt
Bogard_events.txt
Bowman_Rd_events.txt
Buckhorn_events.txt
Cedar_Pass_events.txt
Central_Yreka_events.txt
Collier_events.txt
Cottonwood_Truck_Scales_events.txt
Deschutes_events.txt
Dorris_events.txt
Doyle_events.txt
Dunsmuir_events.txt
EELab_1921_events.txt
East_Riverside_events.txt
Eureka_Way_events.txt
Fawndale_events.txt
Fredonyer_Smt_events.txt
Gibson_events.txt

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

[0 - Main Menu]
[2 - Input / Output Values]
Input: 121.0V 59.9Hz
Output: 119.0V 1.5A 178VA
Battery: 53.2V 23Deg C
*clock=21-07-27 07:51:41

[0 - Main Menu]
[1 - Unit Specification]
Model: FXM1100
Input: 120V 60Hz
Output: 120V 1100VA
Battery: 48V
Software: V2.01.00

*event001=21-07-11 22:06:05 0000000000000000, 0000000000000000, 001
*event002=21-07-11 22:05:58 0000000000000000, 0000000000000000, 006
*event003=21-07-04 22:56:13 0000000000000000, 0000000000000000, 001
*event004=21-07-04 22:55:12 0000000000000000, 0000000000000000, 003
*event005=21-07-04 22:55:07 0000000000000000, 0000000000000000, 001
*event006=21-07-04 22:55:01 1000000000000000, 0000000000000000, 001
*event007=21-07-04 20:23:53 1000000000000000, 0000000000000000, 006
*event008=21-07-04 20:22:50 0000000000000000, 0000000000000000, 006
*event009=21-06-30 13:54:40 0000000000000000, 0000000000000000, 001
*event010=21-06-30 13:54:35 1000000000000000, 0000000000000000, 001
*event011=21-06-30 13:54:30 1000000000000000, 0000000000000000, 006
*event012=21-06-30 13:50:39 1000000010000000, 0000000000000000, 006
*event013=21-06-30 13:49:37 0000000010000000, 0000000000000000, 006
*event014=21-06-30 13:49:36 0000000000000000, 0000000000000000, 006
*event015=21-06-30 10:47:02 0000000000000000, 0000000000000000, 001
*event016=21-06-30 10:46:56 0000000000000000, 0000000000000000, 006
*event017=21-06-24 14:00:45 0000000000000000, 0000000000000000, 001
*event018=21-06-24 14:00:38 0000000000000000, 0000000000000000, 006
*event019=21-06-22 18:37:29 0000000000000000, 0000000000000000, 001
*event020=21-06-22 18:37:28 0000000000000000, 0000000000000000, 003
*event021=21-06-14 18:02:09 0000000000000000, 0000000000000000, 001
*event022=21-06-14 18:02:03 1000000000000000, 0000000000000000, 001
*event023=21-06-14 17:53:33 1000000000000000, 0000000000000000, 006
*event024=21-06-14 17:52:30 0000000000000000, 0000000000000000, 006
*event025=21-06-09 00:49:06 0000000000000000, 0000000000000000, 001

Back

Exam

ents

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site L](#)

Inverter Events

All Sites

Filename
Abrams_Lake_NB_events.txt
Abrams_Lake_SB_events.txt
Abrams_Lake_events.txt
Anderson_Grade_events.txt
Antlers_Bridge_events.txt
Black_Butte_events.txt
Bogard_events.txt
Bowman_Rd_events.txt
Buckhorn_events.txt
Cedar_Pass_events.txt
Central_Yreka_events.txt
Collier_events.txt
Cottonwood_Truck_Scales_events.txt
Deschutes_events.txt
Dorris_events.txt
Doyle_events.txt
Dunsmuir_events.txt
EELab_1921_events.txt
East_Riverside_events.txt
Eureka_Way_events.txt
Fawndale_events.txt
Fredonyer_Smt_events.txt
Gibson_events.txt

[0 - Main Menu]
[2 - Input / Output Values]
Input: 121.0V 59.9Hz
Output: 119.0V 1.5A 178VA
Battery: 53.2V 23Deg C

*clock=21-07-27 07:51:41

[0 - Main Menu]
[1 - Unit Specification]

Model: FXM1100
Input: 120V 60Hz
Output: 120V 1100VA
Battery: 48V
Software: V2.01.00

```
*event001=21-07-11 22:06:05 0000000000000000, 0
*event002=21-07-11 22:05:58 0000000000000000, 0
*event003=21-07-04 22:56:13 0000000000000000, 0
*event004=21-07-04 22:55:12 0000000000000000, 0
*event005=21-07-04 22:55:07 0000000000000000, 0
*event006=21-07-04 22:55:01 1000000000000000, 0
*event007=21-07-04 20:23:53 1000000000000000, 0
*event008=21-07-04 20:22:50 0000000000000000, 0
*event009=21-06-30 13:54:40 0000000000000000, 0
*event010=21-06-30 13:54:35 1000000000000000, 0
*event011=21-06-30 13:54:30 1000000000000000, 0
*event012=21-06-30 13:50:39 1000000010000000, 0
*event013=21-06-30 13:49:37 0000000010000000, 0
*event014=21-06-30 13:49:36 0000000000000000, 0
*event015=21-06-30 10:47:02 0000000000000000, 0
*event016=21-06-30 10:46:56 0000000000000000, 0
*event017=21-06-24 14:00:45 0000000000000000, 0
*event018=21-06-24 14:00:38 0000000000000000, 0
*event019=21-06-22 18:37:29 0000000000000000, 0
*event020=21-06-22 18:37:28 0000000000000000, 0
*event021=21-06-14 18:02:09 0000000000000000, 0
*event022=21-06-14 18:02:03 1000000000000000, 0
*event023=21-06-14 17:53:33 1000000000000000, 0
*event024=21-06-14 17:52:30 0000000000000000, 0
*event025=21-06-09 00:49:06 0000000000000000, 0000000000000000, 001
```

[Back](#)

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

[0 - Main Menu]
[2 - Input / Output Values]
Input: 122.0V 59.9Hz
Output: 122.0V 1.6A 195VA
Battery: 53.2V 16Deg C
*clock=07-27-21 07:47:28

[0 - Main Menu]
[1 - Unit Specification]
Model: FXM1100
Input: 120V 60Hz
Output: 120V 1100VA
Battery: 48V
Software: V1.08.72

```
*event001=07-24-21 21:53:07 0000000000000000, 0000000000000000, 001
*event002=07-24-21 21:53:00 0000000000000000, 0000000000000000, 006
*event003=07-22-21 05:03:46 0000000000000000, 0000000000000000, 001
*event004=07-22-21 05:03:46 0000000000000000, 0000000000000000, 003
*event005=07-19-21 12:06:08 0000000000000000, 0000000000000000, 001
*event006=07-19-21 12:06:01 0000000000000000, 0000000000000000, 006
*event007=07-19-21 12:05:57 00000
```

[Back](#)

Examples – System Logs

Current
System Log

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

[Archive](#)

21-7-26 15:58:00 Logs Rotated

Examples – S

Current System Log

Home | Inverter Events | **System Logs** | Site Logs | Sites Configuration

Archive

21-7-26 15:58:00 Logs Rotated

Back

Archive System Logs

Site Logs

system

Current

Filename	Size	Last Modified
system01.log	30 Bytes	2021-07-01 15:58:00
system02.log	30 Bytes	2021-07-02 15:58:00
system03.log	30 Bytes	2021-07-03 15:58:00
system04.log	30 Bytes	2021-07-04 15:58:00
system05.log	30 Bytes	2021-07-05 15:58:00
system06.log	30 Bytes	2021-07-06 15:58:00
system07.log	30 Bytes	2021-07-07 15:58:00
system08.log	30 Bytes	2021-07-08 15:58:00
system09.log	30 Bytes	2021-07-09 15:58:00
system10.log	30 Bytes	2021-07-10 15:58:00
system11.log	30 Bytes	2021-07-11 15:58:00
system12.log	30 Bytes	2021-07-12 15:58:00
system13.log	30 Bytes	2021-07-13 15:58:00
system14.log	30 Bytes	2021-07-14 15:58:00
system15.log	30 Bytes	2021-07-15 15:58:00
system16.log	30 Bytes	2021-07-16 15:58:00
system17.log	30 Bytes	2021-07-17 15:58:00
system18.log	30 Bytes	2021-07-18 15:58:00
system19.log	30 Bytes	2021-07-19 15:58:00
system20.log	30 Bytes	2021-07-20 15:58:00
system21.log	30 Bytes	2021-07-21 15:58:00
system22.log	30 Bytes	2021-07-22 15:58:00
system23.log	30 Bytes	2021-07-23 15:58:00
system24.log	30 Bytes	2021-07-24 15:58:00
system25.log	30 Bytes	2021-07-25 15:58:00
system26.log	30 Bytes	2021-07-26 15:58:00
system27.log	30 Bytes	2021-06-27 15:58:00
system28.log	30 Bytes	2021-06-28 15:58:00
system29.log	30 Bytes	2021-06-29 15:58:00
system30.log	30 Bytes	2021-06-30 15:58:00
system31.log	30 Bytes	2021-05-31 15:58:00

31 Total Files

Back

Site Logs

All Sites

Archive

Site Logs	Total Size	Number of Files
<u>Abrams_Lake</u>	511 Bytes	3
<u>Abrams_Lake_NB</u>	85 Bytes	3
<u>Abrams_Lake_SB</u>	369 Bytes	3
<u>Anderson_Grade</u>	85 Bytes	3
<u>Antlers_Bridge</u>	85 Bytes	3
<u>Black_Butte</u>	85 Bytes	3
<u>Bogard</u>	85 Bytes	3
<u>Bowman_Rd</u>	85 Bytes	3
<u>Buckhorn</u>	85 Bytes	3
<u>Cedar_Pass</u>	114 Bytes	3
<u>Central_Yreka</u>	85 Bytes	3
<u>Collier</u>	85 Bytes	3
<u>Cottonwood_Truck_Scales</u>	85 Bytes	3
<u>Deschutes</u>	85 Bytes	3
<u>Dorris</u>	85 Bytes	3
<u>Doyle</u>	85 Bytes	3
<u>Dunsmuir</u>	85 Bytes	3
<u>EELab_1921</u>	298 Bytes	3
<u>EELab_SNMP</u>	85 Bytes	3
<u>East_Riverside</u>	85 Bytes	3
<u>Eureka_Way</u>	85 Bytes	3
<u>Fawndale</u>	85 Bytes	3
<u>Fredonyer_Smt</u>	143 Bytes	3
<u>Gibson</u>	85 Bytes	3
<u>Grass_Lake</u>	1789 Bytes	3
<u>Hartnell</u>	4028 Bytes	3
<u>Hatchet_Mtn</u>	1079 Bytes	3
<u>Hilltop</u>	4053 Bytes	3

– Site Logs

Current Site Logs

Site Logs

All Sites

Archive

Site Logs	Total Size	Number of Files
<u>Abrams_Lake</u>	511 Bytes	3
Abrams_Lake_NB	85 Bytes	3
Abrams_Lake_SB	369 Bytes	3
Anderson_Grade	85 Bytes	3
Antlers_Bridge	85 Bytes	3
Black_Butte	85 Bytes	3
Bogard	85 Bytes	3
Bowman_Rd	85 Bytes	3
Buckhorn	85 Bytes	3
Cedar_Pass	114 Bytes	3
Central_Yreka	85 Bytes	3
Collier	85 Bytes	3
Cottonwood_Truck_Scales	85 Bytes	3
Deschutes	85 Bytes	3
Dorris	85 Bytes	3
Doyle	85 Bytes	3
Dunsmuir	85 Bytes	3
EELab_1921	298 Bytes	3
EELab_SNMP	85 Bytes	3
East_Riverside	85 Bytes	3
Eureka_Way	85 Bytes	3
Fawndale	85 Bytes	3
Fredonyer_Smt	143 Bytes	3
Gibson	85 Bytes	3
Grass_Lake	1789 Bytes	3
Hartnell	4028 Bytes	3
Hatchet_Mtn	1079 Bytes	3
Hilltop	4053 Bytes	3

- Site Logs

Current Site Logs

Site Log

Site Logs

Abrams_Lake

Archive

Filename	Size	Last Modified
Abrams_Lake.log	456 Bytes	2021-07-27 04:46:05
Abrams_Lake_SQLevent.log	30 Bytes	2021-07-26 15:58:00
Abrams_Lake_comm.log	25 Bytes	2021-07-27 08:05:35

3 Total Files

Back

Examples – Site Logs

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Site Logs

Abrams_Lake

[Archive](#)

Filename	Size	Last Modified
<u>Abrams_Lake.log</u>	456 Bytes	2021-07-27 04:46:05
Abrams_Lake_SQLEvent.log	30 Bytes	2021-07-26 15:58:00
Abrams_Lake_comm.log	25 Bytes	2021-07-27 08:05:35

3 Total Files

[Back](#)

At least one complete event needed.

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

21-7-27 04:46:05 empty event file found. Either no file or blank file.
21-7-27 04:46:05 empty event file found. Either no file or blank file.
21-7-26 23:56:05 empty event file found. Either no file or blank file.
21-7-26 23:56:05 empty event file found. Either no file or blank file.
21-7-26 18:11:05 empty event file found. Either no file or blank file.
21-7-26 18:11:05 empty event file found. Either no file or blank file.
21-7-26 15:58:00 Logs Rotated

[Back](#)

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site L](#)

[0 - Main Menu]
[2 - Input / Output Values]
Input: 123.0V 60.0Hz
Output: 122.0V 1.1A 134VA
Battery: 53.1V 17Deg C

*clock=07-27-21 08:11:08

[0 - Main Menu]
[1 - Unit Specification]
Model: FXM1100
Input: 120V 60Hz
Output: 120V 1100VA
Battery: 48V
Software: V1.08.72

*event001=07-21-21 05:39:00 0000000000

Examples – Site Logs

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Site Logs

Abrams_Lake

[Archive](#)

Filename	Size	Last Modified
Abrams_Lake.log	456 Bytes	2021-07-27 04:46:05
Abrams_Lake_SQLevent.log	30 Bytes	2021-07-26 15:58:00
Abrams_Lake_comm.log	25 Bytes	2021-07-27 08:05:35

3 Total Files

[Back](#)

No SQL
Errors

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

21-7-26 15:58:00 Logs Rotated

[Back](#)

Some debug
information

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

```
[31, '21-07-27', '06:01:35', '0000000000000000', '0000000000000000', '001', 'Line', '21-06-17', '07:58:49', '21-07-27', '06:02:11', '1627390895.12']
[31, '21-07-27', '06:01:35', '0000000000000000', '0000000000000000', '006', 'Inverter', '21-06-20', '07:58:43', '21-07-27', '06:02:11', '1627390895.12']
[31, '21-07-27', '06:01:35', '0000000000000000', '0000000000000000', '001', 'Line', '21-06-20', '07:58:49', '21-07-27', '06:02:11', '1627390895.12']
[31, '21-07-27', '06:01:35', '0000000000000000', '0000000000000000', '006', 'Inverter', '21-06-23', '07:58:43', '21-07-27', '06:02:11', '1627390895.12']
[31, '21-07-27', '06:01:35', '0000000000000000', '0000000000000000', '001', 'Line', '21-06-23', '07:58:49', '21-07-27', '06:02:11', '1627390895.12']
[31, '21-07-27', '06:01:35', '0000000000000000', '0000000000000000', '006', 'Inverter', '21-06-24', '07:58:43', '21-07-27', '06:02:11', '1627390895.12']
[31, '21-07-27', '06:01:35', '0000000000000000', '0000000000000000', '001', 'Line', '21-06-24', '07:58:49', '21-07-27', '06:02:11', '1627390895.12']
[31, '21-07-27', '06:01:35', '0000000000000000', '0000000000000000', '006', 'Inverter', '21-06-26', '07:58:44', '21-07-27', '06:02:11', '1627390895.12']
[31, '21-07-27', '06:01:35', '0000000000000000', '0000000000000000', '001', 'Line', '21-06-26', '07:58:51', '21-07-27', '06:02:11', '1627390895.11']
```

Examples – Site Logs

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Site Logs

Abrams_Lake

[Archive](#)

Filename	Size	Last Modified
Abrams_Lake.log	456 Bytes	2021-07-27 04:46:05
Abrams_Lake_SQLevent.log	30 Bytes	2021-07-26 15:58:00
<u>Abrams_Lake_comm.log</u>	25 Bytes	2021-07-27 08:05:35

3 Total Files

[Back](#)

Site was reached
by ping

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

21-7-27 08:10:35 Reached

[Back](#)

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

21-7-27 07:57:00 Not reached
21-7-27 06:57:00 Not reached
21-7-27 05:57:00 Not reached
21-7-27 04:57:00 Not reached
21-7-27 03:57:00 Not reached
21-7-27 02:57:00 Not reached
21-7-27 01:57:00 Not reached
21-7-27 00:57:00 Not reached
21-7-26 23:57:00 Not reached
21-7-26 22:57:00 Not reached
21-7-26 21:57:00 Not reached
21-7-26 20:57:00 Not reached

No communications
to site

Site Configuration

All Sites

- On Inverter:
- On Buck/Boost:
- Data is stale (>2Hrs):
- Down for construction:
- Event Occurred Last 24Hrs:

[New Site](#)

Site	IP Address	Firmware	Comm Type FEN/Alpha	Timeout Con/Data	Interval Start/Frequency	Last Update
Abrams_Lake (0)		2.00.01	Cell / Serial	30 / 30	05 / 05	Nov 17 2020 10:24:22
Abrams_Lake_NB (1)		1.08.72	Cell / Serial	30 / 30	04 / 05	Nov 17 2020 09:31:28
Abrams_Lake_SB (0)		2.00.01	Cell / Serial	30 / 30	00 / 05	Nov 17 2020 10:24:25
Anderson_Grade (1)		1.08.72	ISDN / Serial	30 / 60	01 / 15	Nov 17 2020 09:31:28
Antlers_Bridge (1)		1.08.72	MW / Serial	30 / 30	00 / 05	Nov 17 2020 09:31:28
Black_Butte (1)		1.08.72	Cell / Serial	30 / 30	07 / 15	Nov 17 2020 09:31:28
Bogard (1)		1.08.72	POTS / Serial	45 / 90	01 / 15	Nov 17 2020 09:31:28
Bowman_Rd (1)		2.00.04	ISDN / Serial	30 / 30	57 / 60	Nov 17 2020 09:31:28
Buckhorn (1)		2.00.04	ISDN / Serial	30 / 30	09 / 15	Nov 17 2020 09:31:28
Cedar_Pass (1)		1.08.72	POTS / Serial	40 / 90	02 / 60	Nov 17 2020 09:31:28
Central_Yreka (1)		1.08.72	ISDN / Serial	30 / 30	36 / 60	Nov 17 2020 09:31:28
Collier (1)		1.08.72	ISDN / Serial	30 / 30	08 / 60	Nov 17 2020 09:31:28
Cottonwood_Truck_Scales (1)		2.00.04	ISDN / Serial	30 / 30	34 / 60	Nov 17 2020 09:31:28
Deschutes (1)		2.01.00	ISDN / Serial	30 / 30	08 / 60	Nov 17 2020 09:31:28
Dorris (1)		1.08.72	POTS / Serial	30 / 90	08 / 30	Nov 17 2020 09:31:28
Doyle (1)		2.01.00	Cell / Serial	30 / 30	04 / 05	Nov 17 2020 09:31:28
Dunsmuir (1)		1.08.72	Cell / Serial	30 / 30	01 / 05	Nov 17 2020 09:31:28
East_Riverside (1)		1.08.72	POTS / Serial	45 / 90	10 / 60	Nov 17 2020 09:31:28
EELab_1921 (0)		2.01.00	POTS / Serial	30 / 30	01 / 15	Nov 17 2020 10:24:35
EELab_SNMP (0)		2.01.00	POTS / Snmp	30 / 00	02 / 15	Jul 19 2021 23:02:05
Eureka_Way (1)		1.08.72	ISDN / Serial	30 / 60	51 / 60	Nov 17 2020 09:31:28
Fawndale (1)		2.01.00	MW / Snmp	30 / 30	02 / 05	May 06 2021 08:42:01
Fredonyer_Smt (1)		1.08.72	Cell / Serial	30 / 30	02 / 05	May 24 2021 11:20:57
Gibson (1)		2.00.04	ISDN / Serial	30 / 30	04 / 15	Nov 17 2020 09:31:28
Grass_Lake (1)		1.08.72	Cell / Serial	30 / 30	04 / 05	Nov 17 2020 09:31:28
Hartnell (1)		1.08.72	FIBER / Serial	30 / 30	01 / 05	Nov 17 2020 09:31:28
Hatchet_Mtn (1)		1.08.72	Cell / Serial	30 / 30	00 / 05	Nov 17 2020 09:31:28
Hilltop (0)		2.01.00	FIBER / Serial	30 / 30	01 / 05	Nov 17 2020 10:24:46
HilltopUPS (0)		2.01.00	FIBER / Snmp	16 / 30	01 / 05	Jul 19 2021 10:01:00

Site Configuration

All Sites

- On Inverter: █
- On Buck/Boost: █
- Data is stale (>2Hrs): █
- Down for construction: █
- Event Occurred Last 24Hrs: !

[New Site](#)

Site	IP Address	Firmware	Comm Type FEN/Alpha	Timeout Con/Data	Interval Start/Frequency	Last Update
Abrams_Lake (0)		2.00.01	Cell / Serial	30 / 30	05 / 05	Nov 17 2020 10:24:22
Abrams_Lake_NB (1)		1.08.72	Cell / Serial	30 / 30	04 / 05	Nov 17 2020 09:31:28
Abrams_Lake_SB (0)		2.00.01	Cell / Serial	30 / 30	00 / 05	Nov 17 2020 10:24:25
Anderson_Grade (1)		1.08.72	ISDN / Serial	30 / 60	01 / 15	Nov 17 2020 09:31:28
Antlers_Bridge (1)		1.08.72	MW / Serial	30 / 30	00 / 05	Nov 17 2020 09:31:28

Site Details Down for Construction CCTV Image Site Key: 1

Site Name: Site IP Address: Port:

Communication Type: Alpha Communication Type:

Date Format: Firmware:

Timeout Connection(30 Seconds Default): Timeout Data(30 Seconds Default): Battery Manufacture

Set initial retrieval minute: Execute every __ minute(s):

EELab_Snmp (0)		2.01.00	POTS / Snmp	30 / 60	02 / 15	Jul 19 2021 23:02:05
Eureka_Way (1)		1.08.72	ISDN / Serial	30 / 60	51 / 60	Nov 17 2020 09:31:28
Fawndale (1)		2.01.00	MW / Snmp	30 / 30	02 / 05	May 06 2021 08:42:01
Fredonyer_Smt (1)		1.08.72	Cell / Serial	30 / 30	02 / 05	May 24 2021 11:20:57
Gibson (1)		2.00.04	ISDN / Serial	30 / 30	04 / 15	Nov 17 2020 09:31:28
Grass_Lake (1)		1.08.72	Cell / Serial	30 / 30	04 / 05	Nov 17 2020 09:31:28
Hartnell (1)		1.08.72	FIBER / Serial	30 / 30	01 / 05	Nov 17 2020 09:31:28
Hatchet_Mtn (1)		1.08.72	Cell / Serial	30 / 30	00 / 05	Nov 17 2020 09:31:28
Hilltop (0)		2.01.00	FIBER / Serial	30 / 30	01 / 05	Nov 17 2020 10:24:46
HilltopUPS (0)		2.01.00	FIBER / Snmp	16 / 30	01 / 05	Jul 19 2021 10:01:00

Difficulties

- Bash
- Plink
- Moxa
- Alpha

Difficulties – Bash

- Initially was called by Python script using `os.system()`
 - Caused issue when switching from Ubuntu 16.04 to 18.04
 - Function call does not have multiple arguments
 - Keeps connection open after sleep occurs

```
2
clock
event1-25
1
|

[0 - Main Menu]
[2 - Input / Output Values]
Input: 120.5V 60.0Hz
Output: 119.0V 1.6A 190VA
Battery: 53.4V 15Deg C

*clock=09-04-19 10:15:58

[0 - Main Menu]
[1 - Unit Specification]
Model: FXM1100
Input: 120V 60Hz
Output: 120V 1100VA
Battery: 48V
Software: V1.08.72

*event001=09-04-19 06:14:35 0000000000000000, 0000000000000000, 001
*event002=09-04-19 06:14:28 0000000000000000, 0000000000000000, 006
*event003=09-02-19 10:11:50 0000000000000000, 0000000000000000, 001
```

Difficulties – Bash

- Switched to Python subprocess()
 - Supports multiple operating systems
 - Allows the spawning of new processes and connects the input, output and errors

```
commands = '/var/bbs/bbs/bash/commands'
with open(commands, 'r') as f, open(path, 'w') as out:
    test = subprocess.Popen(['timeout', str(Timeout), 'plink', '-ssh', 'user@'+IP, '-P', Port, '-pw', paths.moxpw], stdin=f, stdout=out)
    sleep(int(Timeout) + 5)
    rCode = test.poll()
    if rCode == 0 or rCode == 124:
        return ((rCode == 0) or (rCode == 124))

    test.kill()
    rCode = test.poll()
    return rCode == -9
```

Difficulties – Bash

- Found an issue where `<sleep>` was called in the bash script to close the connection to field site after set time
- On slow sites where the data would take longer to pass. The connection would stay open until all data was passed or the modem closed the connection
- Changed the script to use `<timeout>` with a kill command if time elapsed

Difficulties – Bash

\$1 – IP Address of Field Site
\$2 – File location of Event log

\$4 – Port number of Moxa to BBS Cable
\$5 – Password to Moxa

\$3 – Sleep time

```
#!/bin/bash
ping -w 30 -c 1 $1 > /dev/null
{ cat ./bash/commands; sleep $3; } | ./plink -ssh user@$1 -P $4 -
pw $5 >$2
```

\$TO – Timeout time

```
#!/bin/bash
ping -w 30 -c 1 $1 > /dev/null
TO=$((($3 * 2))
{ cat ./bash/commands; } | timeout $TO plink -ssh user@$1 -P $4 -
pw $5 >$2
```

Difficulties – Plink

- Difference in Plink version 0.67 and 0.70 when accepting certificate
- Original Development was done with Putty version 0.67
- Upon switching to 0.70 Putty security was updated and cyphers were changed

Difficulties – Plink

- The change was caused because development was on Ubuntu 16.04LTS and then transitioned to 18.04LTS the current Ubuntu Linux
- This caused an issue where the key returned from Moxa did not match the required key
- Had to manually compile an older version of Plink so that it functioned correctly

Difficulties – Moxa

- Difference in Moxa version 1.16 and 1.17 when accepting certificate
- Moxa version 1.16 returned wrong key to server
- Resulted in no connection to field site from District Office
- Upon upgrading Moxa to firmware 1.17 key was then accepted

Difficulties – Moxa/Plink

- Once both Moxa and Plink were updated to proper versions certificate and key issues were resolved
- Never found out if one or the other was the main culprit



Difficulties – Alpha FXM 1100

- Command *eventclr does not work
- Date time issue with specific firmware
 - current year is 2019. Tens' place is 1, ones' place is 9, $1*9=9$, $2019+9=2028$, display year is 2028
- Lack of serial commands documentation


Difficulties – Alpha FXM 1100

eventX=12/25/99 01:45:59 0000000000000000, 0000000000000000, 000
Event Date Time Alarm Fault Mode


Date & Time formats depend on selected display format

See below for details on these readouts.

Alarm: When the following bits show a 1, the following alarms are displayed.




Fault: When the following bits show a 1, the following faults are displayed..




Difficulties – Alpha FXM 1100

Alarm: When the following bits show a 1, the following alarms are displayed.




Fault: When the following bits show a 1, the following faults are displayed.




eventX=12/25/99 01:45:51
 Event Date Time

Date & Time formats depend on selected display format

Alarm: When the following bits show a 1, the following alarms are displayed.



Fault: When the following bits show a 1, the following faults are displayed..



Difficulties – Alpha FXM 1100

- Event and Fault codes inconsistent between manual
- Additional Event codes not documented
- Software automatically turning off event logging upon firmware upgrade
 - Defeats the purpose of downloading events

Difficulties – Alpha FXM 1100

- Total number events incorrectly documented
 - States 100 but some Alpha contained 200 events
- Serial application UPS Monitor Software unreliable
- Inability to get all events from application
 - Alpha provided application for serial will crash when attempting to download event list.

Difficulties – Alpha FXM 1100

- Unresponsive technical support
- Ability to perform a firmware upgrade via serial unreliable past firmware 1.08.72



Difficulties – Alpha FXM 1100

- Multiple firmware needed on Alpha's with communication module
- Communication module does not properly work if Alpha firmware does not match



Difficulties – Alpha FXM 1100

- If upgrading Alpha remotely must upgrade com port first
- If upgrading Alpha locally must upgrade Alpha Firmware first



Difficulties – Alpha FXM 1100

- When switching to SNMP only will lose the event history being grabbed from the serial side
- SNMP only gives the current status




Integration

- ITS Engineering and Support
- Transportation Management Center (TMC)

Integration

- ITS Engineering and Support
 - Incorporated into daily checks of system health
 - Shows if a field site is running on battery backup
 - Gives time that this occurred





Integration - PSPS

Current Site Status

All Sites

Data is stale: ■
 Not in line state: ■
 Down for construction: ■
 Awaiting SSH certificate: ■
 Event Occurred Last 24Hrs: !

SPS

Sites With Error							New Site	
Site	Firmware	Communication Type	Current Mode	Power (In, Out, Out, Batt)	Battery Install Date	Last Successful Pull		
Abrams Lake NB	1.08.72	Cell	Line	121.0V 119.0V 154VA 55.0V	-	07:24:35 10-28-2019		
Abrams Lake SB	2.00.01	Cell	Line	122.0V 121.0V 121VA 57.3V	-	07:20:35 10-28-2019		
Anderson Grade	1.08.72	ISDN	Line	118.0V 117.0V 152VA 54.6V	-	04:02:08 10-28-2019		
Antlers Bridge	1.08.72	MW	Inverter	0.0V 120.0V 228VA 42.6V		03:15:35 10-27-2019		
Black Butte	1.08.72	Cell	Line	120.0V 118.0V 177VA 54.9V	-	07:22:35 10-28-2019		
Boqard	1.08.72	POTS	Line	120.0V 120.0V 180VA 54.8V	-	07:18:03 10-28-2019		
Bowman Rd	2.00.04	ISDN	Inverter	0.0V 120.0V 156VA 44.0V		10:58:05 10-27-2019		
Buckhorn	2.00.04	ISDN	Line	116.0V 115.0V 103VA 56.7V	-	07:24:39 10-28-2019		
Cedar Pass	1.08.72	POTS	Line	120.0V 120.0V 120VA 54.7V	-	07:04:10 10-28-2019		
Central Yreka	1.08.72	ISDN	Line	118.5V 114.0V 114VA 54.8V	-	06:36:38 10-28-2019		
Collier	1.08.72	ISDN	Line	121.0V 119.0V 202VA 55.5V	-	07:08:35 10-28-2019		
Cottonwood Truck Scales	2.00.04	ISDN	Inverter	0.0V 120.0V 156VA 43.2V		13:34:37 10-27-2019		
Deschutes	1.08.72	ISDN	Inverter	0.0V 120.0V 132VA 43.1V		08:08:37 10-27-2019		
Dorris	1.08.72	POTS	Line	126.0V 125.0V 137VA 55.1V	-	07:10:05 10-28-2019		
Dovle	2.00.01	Cell	Line	124.0V 124.0V 173VA 36.1V	-	07:24:36 10-28-2019		
Dunsmuir	1.08.72	Cell	Line	119.5V 118.0V 118VA 54.9V	-	07:21:35 10-28-2019		
East Riverside	1.08.72	POTS	Inverter	0.0V 120.0V 96VA 47.4V		07:12:03 10-28-2019		
EELab 1921	2.01.00	POTS	Line	117.0V 116.0V 185VA 54.9V	May 2014	07:17:04 10-28-2019		
EELab SNMP	2.01.00	POTS	Line	118.0V 117.0V 187VA 54.9V	Jan 2010	07:17:00 10-28-2019		
Eureka Way	1.08.72	ISDN	Line	121.0V 120.0V 252VA 55.3V	-	06:51:50 10-28-2019		
Fawndale	1.08.72	MW	Line	121.0V 119.0V 178VA 53.4V	-	13:12:30 05-29-2019		
Fredonver Smt	1.08.72	Cell	Inverter	0.0V 120.0V 192VA 42.0V		06:12:36 10-28-2019		
Gibson	2.00.04	ISDN	Line	117.0V 116.0V 197VA 56.5V	-	07:19:37 10-28-2019		
Grass Lake	1.08.72	Cell	Line	122.5V 122.0V 134VA 54.8V	-	07:24:35 10-28-2019		
Hartnell	1.08.72	FIBER	Line	121.0V 120.0V 168VA 54.5V	-	07:21:35 10-28-2019		
Hatchet Mtn	1.08.72	Cell	Line	122.0V 120.0V 180VA 55.8V	-	07:20:36 10-28-2019		
Hilltop	2.01.00	FIBER	Line	121.0V 120.0V 120VA 54.4V	-	07:21:35 10-28-2019		
HilltopUPS	2.01.00	FIBER	Line	121.0V 120.0V 120VA 54.5V	-	07:21:00 10-28-2019		
Hilt Sandhouse	2.00.04	ISDN	Line	122.0V 120.0V 132VA 55.5V	-	07:17:05 10-28-2019		
I5-SR273	2.00.04	FIBER	Inverter	0.0V 120.0V 192VA 42.6V		05:51:35 10-27-2019		
I5-SR299	2.00.04	FIBER	Line	121.0V 120.0V 180VA 55.5V	-	07:24:35 10-28-2019		
I5-SR44	2.00.04	FIBER	Line	120.5V 119.0V 142VA 54.4V	-	07:23:35 10-28-2019		
I5-SR89	1.08.72	ISDN	Line	120.0V 119.0V 142VA 54.7V	-	06:28:25 10-28-2019		
I5-US97	2.00.04	ISDN	Line	119.0V 119.0V 154VA 56.8V	-	06:25:39 10-28-2019		
Janesville	1.08.72	POTS	Line	121.5V 120.0V 180VA 38.1V	-	22:44:36 10-27-2019		
Jellys Ferry	2.00.04	ISDN	Line	121.0V 119.0V 154VA 56.7V	-	06:32:40 10-28-2019		
Johnson Grade	1.08.72	POTS	Inverter	0.0V 120.0V 132VA 48.1V		06:31:07 10-28-2019		
Lakehead	1.08.72	MW	Inverter	0.0V 120.0V 240VA 42.5V		02:41:35 10-27-2019		
Lake Blvd	2.01.00	MW	Line	122.0V 120.0V 228VA 54.6V	-	07:20:35 10-28-2019		
Lake BlvdUPS	2.01.00	MW	Line	122.0V 120.0V 228VA 54.6V	-	07:20:01 10-28-2019		
Lassen Park	1.08.72	POTS	Line	124.0V 124.0V 223VA 49.2V	-	17:21:33 10-26-2019		
La Moine	1.08.72	MW	Line	116.0V 115.0V 230VA 54.6V	-	07:24:35 10-28-2019		
Montgomery Creek	1.08.72	POTS	Inverter	0.0V 120.0V 156VA 43.0V		11:57:06 10-27-2019		
Mott Rd	1.08.72	ISDN	Inverter	0.0V 120.0V 72VA 48.7V	-	09:06:55 05-28-2019		
Mt Hebron	1.08.72	POTS	Line	117.5V 116.0V 116VA 54.6V	-	06:26:33 10-28-2019		
North Hilt	1.08.72	Cell	Line	126.0V 124.0V 136VA 54.7V	-	07:23:35 10-28-2019		
North Red Bluff	1.08.72	ISDN	Line	120.5V 120.0V 0VA 54.4V	-	06:29:40 10-28-2019		
North Weed	1.08.72	ISDN	Line	119.0V 117.0V 128VA 54.7V	-	07:18:39 10-28-2019		
O'Brien	1.08.72	MW	Inverter	0.0V 120.0V 192VA 42.2V		03:37:35 10-27-2019		

Data is stale: ■

Not in line state: ■

Down for construction: ■

Apply CPU certificate: ■

Current Site Status

All Sites

Sites With Errors

Site	Firmware
Abrams Lake NB	1.08.72
Abrams Lake SB	2.00.01
Anderson Grade	1.08.72
Antlers Bridge	1.08.72
Black Butte	1.08.72
Bogard	1.08.72
Bowman Rd	2.00.04
Buckhorn	2.00.04
Cedar Pass	1.08.72
Central Yreka	1.08.72
Collier	1.08.72
Cottonwood Truck Scales	2.00.04
Deschutes	1.08.72
Dorris	1.08.72
Dovle	2.00.01
Dunsmuir	1.08.72
East Riverside	1.08.72
EELab 1921	2.01.00
EELab SNMP	2.01.00
Eureka Way	1.08.72
Fawndale	1.08.72
Fredonver Smt	1.08.72
Gibson	2.00.04
Grass Lake	1.08.72
Hartnell	1.08.72
Hatchet Mtn	1.08.72
Hilltop	2.01.00
HilltopUPS	2.01.00
Hilt Sandhouse	2.00.04
I5-SR273	2.00.04
I5-SR299	2.00.04
I5-SR44	2.00.04
I5-SR89	1.08.72
I5-US97	2.00.04
Janesville	1.08.72
Jellys Ferry	2.00.04
Johnson Grade	1.08.72
Lakehead	1.08.72
Lake Blvd	2.01.00
Lake BlvdUPS	2.01.00
Lassen Park	1.08.72
La Moine	1.08.72
Montgomery Creek	1.08.72
Mott Rd	1.08.72
Mt Hebron	1.08.72
North Hilt	1.08.72
North Red Bluff	1.08.72
North Weed	1.08.72
O'Brien	1.08.72

OBrien	1.08.72	MW	Inverter	0.0V	120.0V	192VA	42.2V	-	03:37:35	10-27-2019
Oregon Mtn	2.00.04	POTS	Line	125.5V	123.0V	184VA	55.4V	-	07:19:16	10-28-2019
Perez	1.08.72	MW	Line	117.5V	116.0V	162VA	55.1V	-	07:21:35	10-28-2019
Pine Grove	1.08.72	MW	Line	120.5V	120.0V	216VA	54.2V	-	07:23:36	10-28-2019
Pit River Bridge	1.08.72	MW	Inverter	0.0V	120.0V	252VA	42.0V	Jun 2019	05:01:35	10-27-2019
Pollard Flat	2.00.04	ISDN	Line	119.0V	118.0V	177VA	56.0V	-	07:17:37	10-28-2019
Red Bluff	1.08.72	ISDN	Line	121.0V	119.0V	119VA	53.3V	-	07:17:35	10-28-2019
Riverside Ave	1.08.72	FIBER	Line	119.0V	118.0V	153VA	54.5V	-	07:24:35	10-28-2019
Sacramento Hill	1.08.72	MW	Inverter	0.0V	120.0V	216VA	42.3V	-	04:55:35	10-27-2019
Salt Creek	1.08.72	ISDN	Inverter	0.0V	120.0V	132VA	45.3V	-	19:27:37	10-26-2019
Shasta River Bridge	1.08.72	Cell	Line	119.0V	118.0V	165VA	54.7V	-	07:17:36	10-28-2019
Shingletown	1.08.72	POTS	Line	121.0V	121.0V	205VA	51.8V	-	18:01:37	10-26-2019
Sidehill	1.08.72	ISDN	Inverter	0.0V	120.0V	132VA	42.2V	-	19:49:32	06-25-2019
Sims Road	1.08.72	ISDN	Line	118.0V	118.0V	129VA	55.1V	-	07:20:38	10-28-2019
Smith Rd	2.00.04	FIBER	Line	121.0V	119.0V	119VA	55.5V	-	07:21:35	10-28-2019
Snowman	1.08.72	Cell	Line	119.0V	117.0V	117VA	54.8V	-	07:23:35	10-28-2019
South Bonnvievw	2.00.04	FIBER	Line	119.0V	117.0V	152VA	55.5V	-	07:20:35	10-28-2019
South Weed	1.08.72	ISDN	Line	124.0V	123.0V	123VA	49.3V	-	06:53:39	10-28-2019
South Yreka	1.08.72	ISDN	Line	121.5V	120.0V	108VA	56.0V	-	07:04:38	10-28-2019
Spring Garden	1.08.72	POTS	Line	124.5V	125.0V	200VA	56.2V	-	07:24:04	10-28-2019
SR299-SR89	1.08.72	POTS	Line	117.0V	116.0V	150VA	54.9V	-	06:49:38	10-28-2019
SR36-SR44	1.08.72	POTS	Line	125.0V	124.0V	136VA	55.1V	-	21:52:03	10-27-2019
SR36-SR89	1.08.72	MW	Inverter	0.0V	120.0V	168VA	47.1V	-	07:24:37	10-28-2019
SR36-US395	1.08.72	POTS	Inverter	0.0V	120.0V	108VA	47.8V	-	07:24:36	10-28-2019
SR70-SR89	1.08.72	POTS	Inverter	0.0V	120.0V	120VA	44.8V	-	02:56:06	10-28-2019
SR70-US395	1.08.72	POTS	Line	118.5V	118.0V	177VA	55.1V	-	07:01:06	10-28-2019
Summit Dr	1.08.72	ISDN	Line	120.0V	119.0V	130VA	54.9V	-	06:56:20	10-28-2019
Sundial Bridge	1.08.72	FIBER	Line	123.0V	121.0V	157VA	54.1V	-	07:21:35	10-28-2019
Townhill	1.08.72	POTS	Inverter	0.0V	120.0V	132VA	44.3V	-	04:59:35	10-28-2019
Vina	1.08.72	ISDN	Inverter	0.0V	120.0V	108VA	43.9V	-	18:02:40	10-27-2019
Vollmers	1.08.72	ISDN	Line	119.0V	117.0V	198VA	54.3V	-	07:13:37	10-28-2019
Weed Airport	1.08.72	ISDN	Line	121.0V	119.0V	130VA	54.7V	-	07:15:35	10-28-2019
Wilcox Rd NB	1.08.72	ISDN	Line	123.0V	122.0V	170VA	55.3V	-	07:14:40	10-28-2019
Wilcox Rd SB	1.08.72	ISDN	Line	123.0V	121.0V	157VA	54.7V	-	06:40:39	10-28-2019

82 Total Site(s) 3 Down Site(s) 19 Error Site(s) 23 Flagged Site(s) 5 Stale Site(s) 0 Site(s) Need Cert

Integration

- ITS Engineering and Support
 - Allows ITS to have an early warning system before the field site shuts down due to power loss
 - When power loss occurs can check power company info to see if there is a planned power outage before making a field site visit



Pollard Flat CCTV After Delta Fire

Integration

- Transportation Management Center (TMC)
 - Due to advance notice from ITS allows TMC Staff to anticipate the loss of a field site and adjust accordingly

Integration



ment Center (TMC)

from ITS allows TMC Staff to anticipate and adjust accordingly

Integration



ment Center (TMC)

m ITS allows TMC Staff to anticipate
adjust accordingly

[Home](#) | [Inverter Events](#) | [System Logs](#) | [Site Logs](#) | [Sites Configuration](#)

Powered By O3 ITS


Cottonwood Truck Scales Power Stats

Graph 02-10-2019 to 02-16-2019

[View Table](#) | [View Events](#)


[All Graphs](#) | [Input](#) | [Output](#) | [Battery](#)

[Date Range Selector](#) | [Last 4 Hours](#) | [Last 24 Hours](#) | [Last 3 Days](#) | [Last 30 Days](#) | [Last Year](#)



Lessons Learned

- Develop on same OS as that which will be deployed on
- Future proof source code



Lessons Learned

- Open some configuration options for the user
- Add data validation of user input
- Use proper input tag i.e. dropdown, number only, etc.

Site Details

Down for Construction CCTV Image

Site Key: 26

Site Name: Abrams_Lake_NB Site IP Address: Port: 4002

Communication Type: Cell Alpha Communication Type: Serial

Date Format: MM/DD/YY Firmware: 1.08.72

Timeout Connection(30 Seconds Default): 30 Timeout Data(30 Seconds Default): 30 Battery Manufacture

Set initial retrieval minute: 4 Execute every __ minute(s): 5 04 / 01 / 2016

Back Get Site Firmware Get New SSH Key Save


Powered By D2 ITS - [Contributors](#)

Lessons Learned

- Directory structure matters early on and will cause issue when trying to address later
- Slow connections will be encountered, and the background process needs to be able to handle incomplete data
- File permissions matter and will need to be addressed
- Database architecture
- Database sizing

Lessons Learned – Plink

- Since establishes a SSH connection need to accept a certificate when adding a new field site
- Needed a script to automate SSH certificate acceptance



Future


- Switch OS to Red Hat or Red Hat based OS
- Convert code to python3
- Upgrade Alpha units

Future – OS

- Switch OS to Red Hat or Red Hat based OS
 - The way that Caltrans is moving want all servers based on Red Hat



Source: [Wikipedia](#)



CentOS

Source: [Wikipedia](#)



Red Hat

Source: [Red Hat](#)

Future – Python 3

- Convert code to python3
 - When project was started there was no End of Life (EOL) for python2 announced
 - Upon “completion” of project EOL was announced for Python2 January 2020
 - Minimal Changes to code will be needed

```
print "There are no () needed around a print statement in Python2"  
print("The () are required around a print statement in Python3")
```

Future – Alpha

- Upgrade Alpha units
 - Replace older units to allow SNMP
 - Shorter communication time
 - Not relying on Python calling a bash script
 - More support from Alpha
 - The way the industry is moving
 - Less data transferred would also improve reliability of slower sites

Future – Database

- Automate database management
 - Rotate tables
 - Archive tables



Questions?